

December 29, 2016

Mr. Robert Markel Frontier Central School District Building Department 5120 Orchard Avenue Hamburg, New York 14075

Re: Investigation and Sampling of Drinking Water for Lead Concentrations

Dear Mr. Robert Markel:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the Frontier Central School District, including:

Frontier Middle School, 2751 Amsdell Road, Hamburg, NY 14075

This report is prepared to assist the District in complying with the requirements of NYS regulations, SUBPART 67-4: Lead Testing in School Drinking Water, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 15 parts per billion (ppb)".

The Investigation and Sampling was performed on October 4, 2016. The Protocol for the Investigation followed the requirements of NYS regulations as well as USEPA Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 (Executive Summary) of the accompanying report, based upon the sampling and analysis performed, 21 sources of potable water in the Frontier Middle School have been identified as having lead concentrations in water above the NYS Action Level of 15 parts per billion. To comply with NYS regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to Frontier Central School District.

Sincerely,

Stohl Environmental, LLC.

Willege

William K. Sisco Project Manager

Investigation and Sampling Of Sources of Potable Water For Lead Concentrations

Prepared for:

Mr. Robert Markel
Frontier Central School District
Building Department
5120 Orchard Avenue
Hamburg, New York 14075

Prepared by:



ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES

4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219 畲 (716) 312-0070 自 (716) 312-8092 www.stohlenvironmental.com

Conditions as of October 4, 2016



Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports by Building
- 1.5. Laboratory Certifications
- 1.6. Chains of Custody



1.1 Sampling Protocol and Summary of Results:

Stohl Environmental was retained by Frontier Central School District to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

Frontier Middle School, 2751 Amsdell Road, Hamburg, NY 14075

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from all outlets in the Frontier Middle School. Outlets are defined in NYS regulations as: "a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets".

Sampling Protocol:

In accordance with NYS regulations, **Subpart 67-4: Lead Testing in School Drinking Water**, and the EPA guidance document, **'3Ts for Reducing Lead in Drinking Water in Schools"**, Stohl Environmental's protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- Service Connection Sampling: Samples were collected at the service connection as follows:
 - Service Connection Sample: As detailed in EPA guidance documents, this sample is not a first-draw sample. The cold water tap closest to the service connection was opened, and the sample was collected immediately after a change in water temperature was detected, or after 30 seconds.
 - Water Main Sample: This sample was collected at the same location as the Service Connection sample; however, it was collected after water was allowed to run an additional 3 minutes after the temperature change, but not more than 3 minutes and 30 seconds.
- Laboratory Analysis: Samples were submitted following strict chain-of-custody protocols
 to an independent laboratory approved by the NYS Department of Health's Environmental
 Laboratory Approval Program (ELAP).



1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of	Total	First Drav	v Samples	Confirmatory Samples **		
	Sample Event	Number Samples Collected	Number of Samples Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb	Number of Samples Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb	
Frontier Middle School	10/04/2016	149	128	21	0	0	

^{**} Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

Listing of Outlets Requiring Remediation:

		lyzed above the NYS Action Level of 15 pmples and Confirmatory Samples	arts per billion	based upon
Sample #	Sample Type	Classroom or other Location	Fixture/Outlet	Laboratory
			type	Analysis in
				ppb
114.2-12	First Draw	Room 205, Left Wall Sink	Sink	44.4
114.2-13	First Draw	Room 205, Right Wall Sink	Sink	42.2
114.2-14	First Draw	Room 205, End Sink	Sink	26.2
114.2-15	First Draw	Room 205, Window Island, Window Sink	Sink	79.3
114.2-16	First Draw	Room 205, Window Island, Door Sink	Sink	50.3
114.2-17	First Draw	Room 205, Door Island, Window Sink	Sink	67.6
114.2-18	First Draw	Room 205, Door Island, Door Sink	Sink	25.1
114.2-31	First Draw	Room 233, Island Sink	Sink	21.1
114.2-34	First Draw	Room 232, Island Sink	Sink	40.0
114.2-36	First Draw	Room 229A	Sink	25.2
114.2-39	First Draw	Room 229, Island Sink	Sink	44.0
114.2-42	First Draw	Women's Room, Left Sink	Sink	32.9
114.2-47	First Draw	Men's Room, Left Sink	Sink	19.0
114.2-48	First Draw	Men's Room, Left Center Sink	Sink	23.0
114.2-49	First Draw	Men's Room, Right Center Sink	Sink	29.2
114.2-102	First Draw	Football Locker Room	Bubbler	21.2
114.2-116	First Draw	Room 133	Sink	17.1
114.2-128	First Draw	Room 166, Center Sink	Sink	21.7
141.2-133	First Draw	Room 167, Center Sink	Sink	21.2
141.2-134	First Draw	Room 167, Right Sink	Sink	30.0
114.2-141	First Draw	Kitchen, Hand Sink	Sink	19.5



1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration in excess of the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

Stohl File #: 2016L-114.2



1.4 Laboratory Analytical Reports by Building

Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)

Address: 4169 Allendale Parkway

Blasdell, NY 14219

Attn:

Project: Frontier Middle School

Location: 4432 Bayview Rd, Hamburg, NY

Number: 2016L-114.2

Order #: 187662

 Matrix
 Drinking Water

 Received
 10/07/16

 Reported
 12/27/16

PO Number:

Sample ID	Cust. Sample ID	Location					
Parameter		Method	Result	RL*	Units	Analysis Date	Analyst
187662-001	114.2-1	Water Main					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/22/16	SA
187662-002	114.2-2	Water Main					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/22/16	SA
187662-003	114.2-3	Boys Lav Near Rm 217					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/22/16	SA
187662-004	114.2-4	Boys Lav Near Rm 217					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/22/16	SA
187662-005	114.2-5	Boys Lav Near Rm 217					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/22/16	SA
187662-006	114.2-6	Boys Lav Near Rm 217					
Metals An	alysis					10/00/10	
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/22/16	SA
187662-007	114.2-7	Bubbler Near Rm 217					
Metals An	alysis	5DA 000 0 D		5 00	,,	10/00/10	0.4
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/22/16	SA
187662-008	114.2-8	Girls Lav Near Rm 211					
Metals And	alysis	EDA 200 0 Day 2 0	5.00	F 00	/1	40/00/40	CA
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/22/16	SA
187662-009	114.2-9	Girls Lav Near Rm 211					
Metals And	alysis	EDA 200 0 Doy 2 2	.E.00	E 00	/1	12/22/16	C A
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/22/16	SA
187662-010	114.2-10	Girls Lav Near Rm 211					
Metals And	aiysis	EDA 200 0 Dov 2 2	.E 00	E 00	ua/I	10/00/46	64
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/22/16	SA
187662-011	114.2-11	Bubbler Near Rm 211					
Metals And	aiysis	EPA 200.9 Rev 2.2	.E 00	E 00	ua/!	12/22/16	SA
Lead		EFA 200.9 REV 2.2	<5.00	5.00	μg/L	12122/10	SA

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = μ g/kg and Water PPM = mg/L | PPB = μ g/L. The test results reported relate only to the samples submitted.

Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)

4169 Allendale Parkway Address:

Blasdell, NY 14219

Attn:

Project: Frontier Middle School

Location: 4432 Bayview Rd, Hamburg, NY

Number: 2016L-114.2 Order #:

187662

Matrix **Drinking Water** Received 10/07/16 Reported

12/27/16

PO Number:

Sample ID	Cust. Sample ID	Location					
Parameter		Method	Result	RL*	Units	Analysis Date	Analyst
187662-012	114.2-12	Rm 205					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	44.4	10.0	μg/L	12/22/16	SA
187662-013	114.2-13	Rm 205					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	42.2	10.0	μg/L	12/22/16	SA
187662-014	114.2-14	Rm 205					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	26.2	5.00	μg/L	12/22/16	SA
187662-015	114.2-15	Rm 205					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	79.3	25.0	μg/L	12/22/16	SA
187662-016	114.2-16	Rm 205					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	50.3	10.0	μg/L	12/22/16	SA
187662-017	114.2-17	Rm 205					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	67.6	25.0	μg/L	12/22/16	SA
187662-018	114.2-18	Rm 205					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	25.1	5.00	μg/L	12/22/16	SA
187662-019	114.2-19	Rm 204					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	7.20	5.00	μg/L	12/22/16	SA
187662-020	114.2-20	Rm 203					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/22/16	SA
187662-021	114.2-21	Boys Lav Near Rm 229A					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/22/16	SA
187662-022	114.2-22	Boys Lav Near Rm 229A					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/22/16	SA

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = $mg/kg \mid PPB = \mu g/kg$ and Water PPM = $mg/L \mid PPB = \mu g/L$. The test results reported relate only to the samples submitted.

Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)

Address: 4169 Allendale Parkway

Blasdell, NY 14219

Attn:

Project: Frontier Middle School

-Location: 4432 Bayview Rd, Hamburg, NY

Number: 2016L-114.2

Order #:

 Matrix
 Drinking Water

 Received
 10/07/16

 Reported
 12/27/16

187662

PO Number:

Sample ID	Cust. Sample ID	Location					
Parameter		Method	Result	RL*	Units	Analysis Date	Analyst
187662-023	114.2-23	Boys Lav Near Rm 229A					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/22/16	SA
187662-024	114.2-24	Boys Lav Near Rm 229A					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/22/16	SA
187662-025	114.2-25	Bubbler Near Rm 229A					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/22/16	SA
187662-026	114.2-26	Bubbler Near Rm 229A					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/22/16	SA
187662-027	114.2-27	Girls Lav Near Rm 229A					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/22/16	SA
187662-028	114.2-28	Girls Lav Near Rm 229A					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/22/16	SA
187662-029	114.2-29	Girls Lav Near Rm 229A					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/22/16	SA
187662-030	114.2-30	Girls Lav Near Rm 229A					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/22/16	SA
187662-031	114.2-31	Rm 233					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	21.1	5.00	μg/L	12/22/16	SA
187662-032	114.2-32	Rm 233					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	6.95	5.00	μg/L	12/22/16	SA
187662-033	114.2-33	Rm 232					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/22/16	SA

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = μ g/kg and Water PPM = mg/L | PPB = μ g/L. The test results reported relate only to the samples submitted.

Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)

Address: 4169 Allendale Parkway

Blasdell, NY 14219

Attn:

Project: Frontier Middle School

Location: 4432 Bayview Rd, Hamburg, NY

Number: 2016L-114.2

Order #:

187662

MatrixDrinking WaterReceived10/07/16Reported12/27/16

PO Number:

Sample ID	Cust. Sample ID	Location					
Parameter		Method	Result	RL*	Units	Analysis Date	Analyst
187662-034	114.2-34	Rm 232					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	40.0	25.0	μg/L	12/22/16	SA
187662-035	114.2-35	Rm 232					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	11.2	5.00	μg/L	12/22/16	SA
187662-036	114.2-36	Rm 229A					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	25.2	5.00	μg/L	12/22/16	SA
187662-037	114.2-37	Rm 231					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	14.5	5.00	μg/L	12/22/16	SA
187662-038	114.2-38	Rm 231					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	6.81	5.00	μg/L	12/22/16	SA
187662-039	114.2-39	Rm 229					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	44.0	10.0	μg/L	12/22/16	SA
187662-040	114.2-40	Rm 229					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	5.72	5.00	μg/L	12/22/16	SA
187662-041	114.2-41	Rm 227					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	5.33	5.00	μg/L	12/23/16	SA
187662-042	114.2-42	Womens Rm					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	32.9	5.00	μg/L	12/23/16	SA
187662-043	114.2-43	Womens Rm					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	8.80	5.00	μg/L	12/23/16	SA
187662-044	114.2-44	Womens Rm					
Metals An	alysis						
Lead	-	EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	SA

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = $\mu g/kg$ and Water PPM = mg/L | PPB = $\mu g/L$. The test results reported relate only to the samples submitted.

Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)

Address: 4169 Allendale Parkway

Blasdell, NY 14219

Attn:

Project: Frontier Middle School

Location: 4432 Bayview Rd, Hamburg, NY

Number: 2016L-114.2

Order #:

MatrixDrinking WaterReceived10/07/16Reported12/27/16

187662

PO Number:

Sample ID	Cust. Sample ID	Location					
Parameter		Method	Result	RL*	Units	Analysis Date	Analyst
187662-045	114.2-45	Drinking Fountain					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	SA
187662-046	114.2-46	Drinking Fountain					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	SA
187662-047	114.2-47	Mens Rm					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	19.0	5.00	μg/L	12/23/16	SA
187662-048	114.2-48	Mens Rm					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	23.0	5.00	μg/L	12/23/16	SA
187662-049	114.2-49	Mens Rm					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	29.2	5.00	μg/L	12/23/16	SA
187662-050	114.2-50	Boys Lav Near Rm 118					
Metals And	alysis	EDA 000 0 D		5 00	,,	10/00/10	0.4
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	SA
187662-051	114.2-51	Boys Lav Near Rm 118					
Metals And	alysis	EDA 000 0 D		5 00	,,	10/00/10	0.4
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	SA
187662-052	114.2-52	Drinking Fountain					
Metals And	alysis	EDA 200 0 Day 2 2	5.00	F 00	/1	40/00/40	CA
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	SA
187662-053	114.2-53	Girls Lav Near Rm 114					
Metals And	alysis	EDA 200 0 Doy 2 2	.5.00	E 00	/1	12/22/16	C A
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	SA
187662-054	114.2-54	Girls Lav Near Rm 114					
Metals And	aiysis	EPA 200.9 Rev 2.2	Æ 00	5.00	ua/l	12/23/16	SA
Lead			<5.00	5.00	μg/L	12/23/10	SA
187662-055	114.2-55	Girls Lav Near Rm 114					
Metals Ana	aiysis	EPA 200.9 Rev 2.2	-E 00	5.00	ua/l	12/23/16	SA
Leau		LFA 200.9 REV 2.2	<5.00	5.00	μg/L	12/23/10	SA

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = μ g/kg and Water PPM = mg/L | PPB = μ g/L. The test results reported relate only to the samples submitted.

Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)

Address: 4169 Allendale Parkway

Blasdell, NY 14219

Attn:

Project: Frontier Middle School

Location: 4432 Bayview Rd, Hamburg, NY

Number: 2016L-114.2

Order #:

187662

 Matrix
 Drinking Water

 Received
 10/07/16

 Reported
 12/27/16

PO Number:

Sample ID	Cust. Sample ID	Location					
Parameter		Method	Result	RL*	Units	Analysis Date	Analyst
187662-056	114.2-56	Girls Lav Near Rm 114					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	SA
187662-057	114.2-57	Bubbler Near Rm 114					
Metals And	alysis					10/00/10	
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	SA
187662-058	114.2-58	Rm 109					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	5.88	5.00	μg/L	12/23/16	SA
187662-059	114.2-59	Rm 106 B					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	SA
187662-060	114.2-60	Rm 106 C					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	SA
187662-061	114.2-61	Rm 106 A					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	SA
187662-062	114.2-62	Rm 106 A					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	SA
187662-063	114.2-63	Rm 106 A					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	SA
187662-064	114.2-64	Rm 106 A					
Metals And	alysis	ED. 000 0 =				404055	
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	SA
187662-065	114.2-65	Rm 104					
Metals And	alysis				c		
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	SA
187662-066	114.2-66	Bubbler Near Rm 104					
<i>Metals And</i> Lead	alysis	EPA 200.9 Rev 2.2	12.3	5.00	μg/L	12/23/16	SA

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = $\mu g/kg$ and Water PPM = mg/L | PPB = $\mu g/L$. The test results reported relate only to the samples submitted.

Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)

4169 Allendale Parkway Address:

Blasdell, NY 14219

Attn:

Project: Frontier Middle School

Location: 4432 Bayview Rd, Hamburg, NY

Number: 2016L-114.2 Order #:

187662

Matrix **Drinking Water** Received 10/07/16 Reported

12/27/16

PO Number:

Sample ID	Cust. Sample ID	Location					
Parameter		Method	Result	RL*	Units	Analysis Date	Analyst
187662-067	114.2-67	Womens Rm					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	SA
187662-068	114.2-68	Mens Rm					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	SA
187662-069	114.2-69	Rm 165					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	SA
187662-070	114.2-70	Rm 165					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	SA
187662-071	114.2-71	Rm 161					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	SA
187662-072	114.2-72	Rm 161					
Metals An	alysis	FD				10/00/10	
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	SA
187662-073	114.2-73	Rm 161					
Metals An	alysis	EDA 000 0 D 0 0		5 00	,,	10/00/10	0.4
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	SA
187662-074	114.2-74	Rm 161					
Metals And	alysis	EDA 200 0 Day 2 2	5.00	F 00	/1	40/00/40	CA
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	SA
187662-075	114.2-75	Rm 161					
Metals And	alysis	EDA 200 0 Doy 2.2	.F. 00	F 00	/1	10/00/16	C A
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	SA
187662-076	114.2-76	Rm 161					
Metals And	aiysis	EPA 200.9 Rev 2.2	-E 00	5.00	ua/l	12/23/16	SA
Lead			<5.00	5.00	μg/L	12/23/10	SA
187662-077	114.2-77	Rm 159					
<i>Metals An</i> Lead	aiysis	EPA 200.9 Rev 2.2	-E 00	5.00	ua/l	12/23/16	SA
LEdu		LFA 200.9 Nev 2.2	<5.00	5.00	μg/L	12/23/10	SA

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = $\mu g/kg$ and Water PPM = mg/L | PPB = $\mu g/L$. The test results reported relate only to the samples submitted.

Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)

Address: 4169 Allendale Parkway

Blasdell, NY 14219

Attn:

Project: Frontier Middle School

-Location: 4432 Bayview Rd, Hamburg, NY

Number: 2016L-114.2

Order #: 187662

 Matrix
 Drinking Water

 Received
 10/07/16

 Reported
 12/27/16

PO Number:

Sample ID	Cust. Sample ID	Location					
Parameter		Method	Result	RL*	Units	Analysis Date	Analyst
187662-078	114.2-78	Rm 159					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	SA
187662-079	114.2-79	Rm 159					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	SA
187662-080	114.2-80	Rm 159					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	SA
187662-081	114.2-81	Rm 159					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	MBH
187662-082	114.2-82	Rm 159					
Metals An	alysis				_		
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	MBH
187662-083	114.2-83	Boys Lav Across Rm 155					
Metals An	alysis	FD4 000 0 D 000		5 00		10/00/10	MOU
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	MBH
187662-084	114.2-84	Boys Lav Across Rm 155					
Metals And	alysis	FDA 000 0 Day 0 0		5.00		40/00/40	MDII
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	MBH
187662-085	114.2-85	Boys Lav Across Rm 155					
Metals And	aiysis	EPA 200.9 Rev 2.2	<5.00	5.00	ua/l	12/23/16	MBH
	444.0.00		<5.00	5.00	μg/L	12/23/10	IVIDIT
187662-086	114.2-86	Boys Lav Across Rm 155					
<i>Metals An</i> Lead	aiysis	EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	MBH
	4440.07		<5.00	3.00	µ9/∟	12/23/10	IVIDIT
187662-087	114.2-87	Drinking Fountain					
<i>Metals An</i> Lead	aiyələ	EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	MBH
	114 2 00		\J.00	0.00	μ α , ∟	12,20,10	.41011
187662-088	114.2-88	Bubbler					
<i>Metals An</i> Lead	aiyəiə	EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	MBH
Loud		L1 / (200.0 1 (CV 2.2	₹3.00	0.00	P9' □	12/20/10	ווטוו

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = $\mu g/kg$ and Water PPM = mg/L | PPB = $\mu g/L$. The test results reported relate only to the samples submitted.

Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)

4169 Allendale Parkway Address:

Blasdell, NY 14219

Attn:

Project: Frontier Middle School

Location: 4432 Bayview Rd, Hamburg, NY

Number: 2016L-114.2 Order #:

187662

Matrix **Drinking Water** Received 10/07/16 Reported

12/27/16

PO Number:

Sample ID	Cust. Sample ID	Location					
Parameter		Method	Result	RL*	Units	Analysis Date	Analyst
187662-089	114.2-89	Girls Lav Across Rm 150B					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	MBH
187662-090	114.2-90	Girls Lav Across Rm 150B					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	MBH
187662-091	114.2-91	Girls Lav Across Rm 150B					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	MBH
187662-092	114.2-92	Girls Lav Across Rm 150B					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	MBH
187662-093	114.2-93	Rm 141					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	MBH
187662-094	114.2-94	Rm 141					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	MBH
187662-095	114.2-95	Rm 141					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	MBH
187662-096	114.2-96	Rm 142					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	11.1	5.00	μg/L	12/23/16	MBH
187662-097	114.2-97	Rm 142					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	5.98	5.00	μg/L	12/23/16	MBH
187662-098	114.2-98	Rm 142					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	7.21	5.00	μg/L	12/23/16	MBH
187662-099	114.2-99	Boys Locker Rm					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	MBH

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = $mg/kg \mid PPB = \mu g/kg$ and Water PPM = $mg/L \mid PPB = \mu g/L$. The test results reported relate only to the samples submitted.

Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)

Address: 4169 Allendale Parkway

Blasdell, NY 14219

Attn:

Project: Frontier Middle School

Location: 4432 Bayview Rd, Hamburg, NY

Number: 2016L-114.2

Order #:

MatrixDrinking WaterReceived10/07/16Reported12/27/16

187662

PO Number:

Sample ID	Cust. Sample ID	Location					
Parameter		Method	Result	RL*	Units	Analysis Date	Analyst
187662-100	114.2-100	Boys Locker Rm					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	MBH
187662-101	114.2-101	Boys Locker Rm					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	MBH
187662-102	114.2-102	Football Locker Rm					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	21.2	5.00	μg/L	12/23/16	MBH
187662-103	114.2-103	Football Locker Rm					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	MBH
187662-104	114.2-104	Rm 145					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	7.92	5.00	μg/L	12/23/16	MBH
187662-105	114.2-105	Rm 148					
Metals And	alysis	5D				10/00/10	
Lead		EPA 200.9 Rev 2.2	7.79	5.00	μg/L	12/23/16	MBH
187662-106	114.2-106	Rm 149B					
Metals And	alysis	EDA 000 0 D 0 0		5 00	,,	10/00/10	MOLL
Lead		EPA 200.9 Rev 2.2	9.05	5.00	μg/L	12/23/16	MBH
187662-107	114.2-107	Bubbler					
Metals And	alysis	EDA 200 0 Day 2 2	5.00	F 00	/1	40/00/40	MDII
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	MBH
187662-108	114.2-108	Rm 149A					
Metals And	alysis	EDA 200 0 Doy 2 2	C 4C	E 00	/1	10/00/16	MBH
Lead		EPA 200.9 Rev 2.2	6.46	5.00	μg/L	12/23/16	IVIDIT
187662-109	114.2-109	Rm 137					
Metals And	aiysis	EPA 200.9 Rev 2.2	0.05	5.00	ua/l	12/23/16	MBH
Lead			9.05	5.00	μg/L	12/23/10	IVIDIT
187662-110	114.2-110	Rm 137					
Metals Ana	aıysıs	EPA 200.9 Rev 2.2	6.04	5.00	ua/l	12/23/16	MBH
Leau		LFA 200.9 REV 2.2	6.81	5.00	μg/L	12/23/10	IVIDIT

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = $\mu g/kg$ and Water PPM = mg/L | PPB = $\mu g/L$. The test results reported relate only to the samples submitted.

Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)

4169 Allendale Parkway Address:

Blasdell, NY 14219

Attn:

Project: Frontier Middle School

Location: 4432 Bayview Rd, Hamburg, NY

Number: 2016L-114.2 Order #:

187662

Matrix **Drinking Water** Received 10/07/16 Reported

12/27/16

PO Number:

Sample ID	Cust. Sample ID	Location					
Parameter		Method	Result	RL*	Units	Analysis Date	Analyst
187662-111	114.2-111	Rm 137					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	MBH
187662-112	114.2-112	Rm 135					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	9.55	5.00	μg/L	12/23/16	MBH
187662-113	114.2-113	Rm 135					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	6.20	5.00	μg/L	12/23/16	MBH
187662-114	114.2-114	Rm 135					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	MBH
187662-115	114.2-115	Rm 135					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/23/16	MBH
187662-116	114.2-116	Rm 133					
Metals Ana	alysis	5D4 000 0 D 0 0		5 00		10/00/10	MOUL
Lead		EPA 200.9 Rev 2.2	17.1	5.00	μg/L	12/23/16	MBH
187662-117	114.2-117	Rm 134					
Metals Ana	alysis	5D4 000 0 D 0 0		5 00		10/00/10	MOUL
Lead		EPA 200.9 Rev 2.2	5.16	5.00	μg/L	12/23/16	MBH
187662-118	114.2-118	Rm 134					
Metals Ana	alysis	EDA 200 0 Day 2 2	7.40	F 00		40/00/40	MDII
Lead		EPA 200.9 Rev 2.2	7.10	5.00	μg/L	12/23/16	MBH
187662-119	114.2-119	Rm 134					
<i>Metals Ana</i> Lead	aiysis	EPA 200.9 Rev 2.2	<5.00	5.00	ua/l	12/23/16	MBH
			<5.00	5.00	μg/L	12/23/10	IVIDIT
187662-120	114.2-120	Rm 131					
<i>Metals Ana</i> Lead	aiysis	EPA 200.9 Rev 2.2	<5.00	5.00	ug/l	12/23/16	MBH
	444.0.404		<5.00	5.00	μg/L	12/23/10	IVIDIT
187662-121	114.2-121	Rm 131					
<i>Metals Ana</i> Lead	aiysis	EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/25/16	MBH
Leau		LFA 200.3 NGV 2.2	<0.00	5.00	µ9/∟	12/23/10	INDIT

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = $mg/kg \mid PPB = \mu g/kg$ and Water PPM = $mg/L \mid PPB = \mu g/L$. The test results reported relate only to the samples submitted.

Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)

Address: 4169 Allendale Parkway

Blasdell, NY 14219

Attn:

Project: Frontier Middle School

-Location: 4432 Bayview Rd, Hamburg, NY

Number: 2016L-114.2

Order #: 187662

 Matrix
 Drinking Water

 Received
 10/07/16

 Reported
 12/27/16

PO Number:

Sample ID	Cust. Sample ID	Location					
Parameter		Method	Result	RL*	Units	Analysis Date	Analyst
187662-122	114.2-122	Rm 131					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/25/16	MBH
187662-123	114.2-123	Rm 131					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/25/16	MBH
187662-124	114.2-124	Rm 131					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/25/16	MBH
187662-125	114.2-125	Rm 131					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/25/16	MBH
187662-126	114.2-126	Rm 137					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/25/16	MBH
187662-127	114.2-127	Rm 166					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/25/16	MBH
187662-128	114.2-128	Rm 166					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	21.7	5.00	μg/L	12/25/16	MBH
187662-129	114.2-129	Rm 166					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	8.91	5.00	μg/L	12/25/16	MBH
187662-130	114.2-130	Drinking Fountain					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/25/16	MBH
187662-131	114.2-131	Drinking Fountain					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/25/16	MBH
187662-132	114.2-132	Rm 167					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	14.0	5.00	μg/L	12/25/16	MBH

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = $\mu g/kg$ and Water PPM = mg/L | PPB = $\mu g/L$. The test results reported relate only to the samples submitted.

Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)

Address: 4169 Allendale Parkway

Blasdell, NY 14219

Attn:

Project: Frontier Middle School

Location: 4432 Bayview Rd, Hamburg, NY

Number: 2016L-114.2

Order #:

PO Number:

187662

 Matrix
 Drinking Water

 Received
 10/07/16

 Reported
 12/27/16

Sample ID Parameter	Cust. Sample ID	Location Method	Result	RL*	Units	Analysis Date	Δnalvet
187662-133	114.2-133	Rm 167	ricouit	116	Onits	Allalysis Date	Anaiyət
Metals Ana		11111101					
Lead	a.yo.o	EPA 200.9 Rev 2.2	21.2	5.00	μg/L	12/25/16	MBH
187662-134	114.2-134	Rm 167					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	30.0	5.00	μg/L	12/25/16	MBH
187662-135	114.2-135	Rm 172					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/25/16	MBH
187662-136	114.2-136	Rm 168					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/25/16	MBH
187662-137	114.2-137	Rm 126					
Metals Ana	alysis				_		
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/25/16	MBH
187662-138	114.2-138	Rm 122					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/25/16	MBH
187662-139	114.2-139	Kitchen					
Metals And	alysis	5D				10/07/10	
Lead		EPA 200.9 Rev 2.2	6.95	5.00	μg/L	12/25/16	MBH
187662-140	114.2-140	Kitchen					
Metals And	alysis	EDA 000 0 Day 0 0		5.00		40/05/40	MDII
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/25/16	MBH
187662-141	114.2-141	Kitchen					
Metals Ana	alysis	EPA 200.9 Rev 2.2	40.5	F 00	//	12/25/16	MBH
			19.5	5.00	μg/L	12/25/16	MBH
187662-142	114.2-142	Kitchen					
<i>Metals And</i> Lead	aıysıs	EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/25/16	MBH
187662-143	114.2-143	Kitchen	10100	2.00	F-5-		
Metals Ana	=						
Lead	,	EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/25/16	MBH

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = $\mu g/kg$ and Water PPM = mg/L | PPB = $\mu g/L$. The test results reported relate only to the samples submitted.

SLG!"

Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)

Address: 4169 Allendale Parkway

Blasdell, NY 14219

Attn:

Project: Frontier Middle School

Location: 4432 Bayview Rd, Hamburg, NY

LNumber: 2016L-114.2

Order #:

187662

Matrix Received Reported Drinking Water

10/07/16 12/27/16

PO Number:

Sample ID	Cust. Sample ID	Location					
Parameter		Method	Result	RL*	Units	Analysis Date	Analyst
187662-144	114.2-144	Kitchen					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/25/16	MBH
187662-145	114.2-145	Kitchen					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/25/16	MBH
187662-146	114.2-146	Kitchen					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/25/16	MBH
187662-147	114.2-147	Kitchen					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/25/16	MBH
187662-148	114.2-148	Rm 116D					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	12/25/16	MBH
187662-149	114.2-149	Basement Sink					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	7.53	5.00	μg/L	12/25/16	MBH

187662-12/27/16 12:50 PM

Abisola O Kasali
Reviewed By: Abisola Kasali

Reviewed By: **Abisola Kasali**Metals Supervisor

EPA Regulatory Limits

 $\begin{array}{ccc} \text{Parameter} & \text{Reg. Limit} & \text{Unit} \\ \text{Lead} & 15.0 & \text{$\mu\text{g/L}$} \end{array}$



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)

Address: 4169 Allendale Parkway

Blasdell, NY 14219

Attn:

Project: Frontier Middle School

-Location: 4432 Bayview Rd, Hamburg, NY

LNumber: 2016L-114.2

Order #: 187662

Matrix Drinking Water

Received 10/07/16 **Reported** 12/27/16

PO Number:

Sample ID	Cust. Sample ID	Location										
Parameter		Method		Re	Result		RL*		Units	Analysis Date	Analyst	
Certification	<u>ons</u>											
Parameter	Method	Matrix	CA	СТ	FL	ND	NJ	NY	RI	VA		
Lead	EPA 200.9 Rev 2.2	Drinking Water	Х	Χ	Х	Χ	Χ	Х	Χ	Χ		
<u>Key</u>												
State	Regulatory Agency	y - Lab ID		Certificate Number								
CA	CA ELAP				2078							
CT	CT DPH				PH-0	118						
FL	FL ELAP				E878	28						
ND	North Dakota				R-221							
NJ	NJDEP				NLC1	60001						
NY	NYELAP-11413				55043	3						
RI	RIDOH				LAO0	0084						
VA	Virginia DCLS/DEQ	- 460135			8615							

^{&#}x27;X' indicates that the analyte is accredited.

If your state is not listed above, call laboratory for accreditation/certification information.



1.5 Laboratory Certifications



Expires 12:01 AM April 01, 2017 Issued September 22, 2016

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. FAYEZ ABOUZAKI SCHNEIDER LABORATORIES GLOBAL, INC 2512 WEST CARY STREET RICHMOND, VA 23220-5117

NY Lab Id No: 11413

is hereby APPROVED as an Environmental Laboratory in conformance with the National Environmental Laboratory Accreditation Conference Standards (2003) for the category ENVIRONMENTAL ANALYSES POTABLE WATER All approved analytes are listed below:

Metals I

Lead, Total

EPA 200.9 Rev. 2.2



ork Department TATE of Health

Serial No.: 55043

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.





Expires 12:01 AM April 01, 2017 Issued April 01, 2016

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. FAYEZ ABOUZAKI SCHNEIDER LABORATORIES GLOBAL, INC 2512 WEST CARY STREET RICHMOND, VA 23220-5117 NY Lab Id No: 11413

is hereby APPROVED as an Environmental Laboratory in conformance with the National Environmental Laboratory Accreditation Conference Standards (2003) for the category ENVIRONMENTAL ANALYSES NON POTABLE WATER

All approved analytes are listed below:

Metals I

Lead, Total EPA 200.7 Rev. 4.4

EPA 6010C EPA 7000B

EPA 3020A

EPA 200.9 Rev. 2.2

Sample Preparation Methods

EPA 3010A EPA 3005A

ork Department TATE of Health

Serial No.: 54667

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.





Expires 12:01 AM April 01, 2017 Issued April 01, 2016

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. FAYEZ ABOUZAKI SCHNEIDER LABORATORIES GLOBAL, INC 2512 WEST CARY STREET RICHMOND, VA 23220-5117 NY Lab Id No: 11413

EPA 8082A

EPA 3050B EPA 3550C EPA 3031

is hereby APPROVED as an Environmental Laboratory in conformance with the National Environmental Laboratory Accreditation Conference Standards (2003) for the category ENVIRONMENTAL ANALYSES SOLID AND HAZARDOUS WASTE All approved analytes are listed below:

	All approved analytes are listed below.				
Characteristic Testing		Polychlorinated Biphenyls			
TCLP	EPA 1311	PCB-1268			
Metals I		Sample Preparation Methods			
Barium, Total	EPA 6010C				
Cadmium, Total	EPA 6010C				
Chromium, Total	EPA 6010C	k Department			
Lead, Total	EPA 6010C				
	EPA 7000B	of Health			
Nickel, Total	EPA 6010C				
Silver, Total	EPA 6010C				
Metals II					
Antimony, Total	EPA 6010C				
Arsenic, Total	EPA 6010C				
Chromium VI	EPA 7196A				
Mercury, Total	EPA 7471B				
Selenium, Total	EPA 6010C				
Polychlorinated Biphenyls					
PCB-1016	EPA 8082A				
PCB-1221	EPA 8082A				
PCB-1232	EPA 8082A				
PCB-1242	EPA 8082A				
PCB-1248	EPA 8082A				
PCB-1254	EPA 8082A				

Serial No.: 54668

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.

EPA 8082A

EPA 8082A



PCB-1260

PCB-1262



Expires 12:01 AM April 01, 2017 Issued April 01, 2016

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. FAYEZ ABOUZAKI SCHNEIDER LABORATORIES GLOBAL, INC 2512 WEST CARY STREET RICHMOND, VA 23220-5117 NY Lab Id No: 11413

is hereby APPROVED as an Environmental Laboratory for the category ENVIRONMENTAL ANALYSES SOLID AND HAZARDOUS WASTE All approved subcategories and/or analytes are listed below:

Miscellaneous

Asbestos in Friable Material

EPA 600/M4/82/020

Asbestos in Non-Friable Material-PLM

Item 198.6 of Manual (NOB by PLM)

Lead in Dust Wipes

EPA 7000B

Lead in Paint

EPA 7000B

EPA 3050B

Sample Preparation Methods

YORK STATE

W Department ATE of Health

Serial No.: 54669

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



Expires 12:01 AM April 01, 2017 Issued April 01, 2016

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. FAYEZ ABOUZAKI SCHNEIDER LABORATORIES GLOBAL, INC 2512 WEST CARY STREET RICHMOND, VA 23220-5117 NY Lab Id No: 11413

is hereby APPROVED as an Environmental Laboratory for the category ENVIRONMENTAL ANALYSES AIR AND EMISSIONS
All approved subcategories and/or analytes are listed below:

Metals I

Lead, Total NIOSH 7082

40 CFR PART 50 1984 APP G

Miscellaneous

Fibers NIOSH 7400 A RULES

YORK STATE Department of Health

Serial No.: 54670

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



1.6 Chains of Custody



Time:

Time:

Time:

Submitted to: (Lab Name)

Contact: Bob Markel

Schneider

CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES 4169 ALLENDALE PKWY: BUFFALO, New York 14219

(716) 312-0070 B (716) 312-8092

www.stohlanvironmental.com

Frontier CSD

Analysis (Name / Lab):

Archived / Released:

QA/QC Review (Name / Lab):

Client:

STOHL Job#

2016L-114.2

5	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
Sample # 114.2-1	Water main	HB	12:42	NA NA		
114.2-1	Water main	НВ	12:49	NA NA		
114.2-3	Boys lav near rm 217	s	10:11	NA	187662	S (1) 1111 1111 1111
114.2-3	Boys lav near m 217	s	10:11	NA NA		
114.2-5	Boys lav near rm 217	s	10:11	NA.	V:\18	7\187662
114.2-5	Boys lav near rm 217	s	10:11	NA	tłyncin	10/7/2016 3:0 3:0
114.2-7	Bubbler near rm 217	В	10:13	NA	Federal Express	77739)9
114.2-8	Girls lav near rm 211	s	10:17	NA.		
114.2-9	Girls lav near rm 211	S	10:17	NA		
114.2-10	Girls lav near rm 211	S	10:17	NA		
114.2-11	Bubbler near rm 211	В	10:19	NA		
114.2-12	rm 205	S	10:21	NA		
114.2-13	rm 205	s	10:21	NA		
114.2-14	rm 205	s	10:21	NA		
114,2-15	rm 205	s	10:21	NA		
114.2-16	rm 205	S	10:21	NA		
114.2-17	rm 205	s	10:21	NA		
114.2-18	rm 205	S	10:21	NA		
114.2-18 es: ase e-mail lai	m 205 o results to labs@stohlenv.co	S If ch	10:21 ecked, also e-m	NA ail results to:	Data: 40///2046	
oled By:	John Robinson	Print Name	Stohl Env:	John Robinson	Date: 10/4/2016	·
	gh-	Print Name	Stohl Env:	Joseph Mecca	Date: 10/5/2016	

Date:

Date:

Date:

QA/QC InterLAB Use:

Page



Submitted to: (Lab Name)

ENVIRONMENTAL CONSULTANTS - AMEMBER OF THE STOHL GROUP OF COMPANIES
4169 ALLENDALE PKWY: BUFFALO, New York 14219

***(716)312-0076 ***(716)312-8092

***www.stohlenvironmental.com*

Client: Frontier CSD Contact: Bob Markel

Building: Frontier Middle School Location: 4432 Bayview Rd, Hamburg, NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9

X 5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
114.2-19	rm 204	S	12:28	NA		
114.2-20	rm 203	S	10:29	NA		
114.2-21	Boys lav near rm 229a	S	10:31	NA		
114.2-22	Boys lav near rm 229a	S	10:31	NA		
114.2-23	Boys lav near rm 229a	S	10:31	NA		
114.2-24	Boys lav near rm 229a	S	10:31	NA	L	
114.2-25	Bubbler near rm 229a	В	10:35	NA		
114.2-26	Bubbler near rm 229a	В	10:35	NA		
114.2-27	Girls lav near rm 229a	S	. 10:37	NA		
114.2-28	Girls lav near rm 229a	S	10:37	NA		_ <u>\</u>
114.2-29	Girls lav near rm 229a	S	10:37	NA		
114.2-30	Girls lav near rm 229a	S	10:37	NA		
114.2-31	rm 233	S	10:41	NA		
114.2-32	rm 233	S	10:41	NA		·
114.2-33	rm 232	S	10:44	NA		·
114.2-34	rm 232	S	10:45	NA NA		
114.2-35	rm 232	S	10:45	NA		
114.2-36	rm 229a	s	10:47	NA		

Notes: Please e-mail lab results to labs	s@stohlenv.com		: : : : : : : : : : : : : : : : : : :
Sampled By: John Robins	· · · · · · · · · · · · · · · · · · ·	Stohl Env: John Robinson	Date: 10/4/2016
Relinquished By:	Print Name	Stohl Env: Joseph Mecca	Date: 10/5/2016
Received (Name / Lab):		Date:	Time:
Sample Login (Name / Lab):		Date:	Time:
Analysis (Name / Lab):		Date:	Time:
QA/QC Review (Name / Lab):		Date:	Time:
Archived / Released:	_QA/QC InterLAB Use:	Date:	Time:

Page <u>2</u> of <u>9</u>



Submitted to: (Lab Name)

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES

4169 ALLENDALE PKWY. BUFALO, NEW YORK 14219

(716) 312-0070 (716) 312-0092

www.stohlenvironmental.com

Client: Frontier CSD

Contact: Bob Markel

Building: Frontier Middle School

Location: 4432 Bayview Rd, Hamburg, NY

Turnaround

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9

X

5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
114.2-37	rm 231	S	10:49	NA		
114.2-38	rm 231	S	10:49	NA		
114.2-39	rm 229	S	10:51	NA NA		
114,2-40	rm 229	S	10:51	NA .		
114.2-41	rm 227	S	10:54	NA		
114,2-42	Women's m	S	10:55	NA		
114.2-43	Women's m	S	10:55	NA		
114.2-44	Women's rm	S	10:55	NA NA		
114.2-45	Drinking fountain	DF	10:59	NA NA		
114.2-46	Drinking fountain	DF	10:59	NA		
114.2-47	Men's m	S	10:58	NA		
114.2-48	Men's m	S	10:58	NA .		
114.2-49	Men's m	S	10:58	NA .		
114.2-50	Boys lav near rm 118	S	11:03	NA NA		
114.2-51	Boys lav near rm 118	S	11:03	NA		<u> </u>
114,2-52	Drinking fountain	Df	11:05	Oasisp8am-100		
114.2-53	Girls lav near rm 114	s	11:07	NA NA		
114.2-54	Girls lav near rm 114	S	11:07	NA NA		

Notes: Please e-mail lab	results to labs@stohlenv.	com				
Sampled By:	John Robinson	Print Name	Stohl Env:	John Robinson	Date: 10/4/2016	
Relinquished By:	Od -	Print Name	Stohl Env:	Joseph Mecca	Date: 10/5/2016	
Received (Name	/ Lab):		Date:		Time:	
Sample Login (Na	ame / Lab):	· · · · · · · · · · · · · · · · · · ·	Date:		Time:	
Analysis (Name /	Lab):		Date:		Time:	
QA/QC Review (N	Name / Lab):		Date:	· · · · · · · · · · · · · · · · · · ·	Time:	
Archived / Releas	sed:QA/QC Int	erLAB Use:	Date:	· · · · · · · · · · · · · · · · · · ·	Time:	
					•	•

Page <u>3</u> of <u>9</u>



Submitted to: (Lab Name)

Schneider

4169-ALLENDALE PKWY. BUFFALO, NEW YORK 14219

(716)-312-0070: (716)-312-6092

www.stohlonvironmental.com

HESTOHLGROUP OF COMPANIES 5 I UTIL JO

STOHL Job # 2016L-114.2

AD ter by AAS-GF:	: ASTM D3559-03D, US EF	A 200.9	X	Turnaround 5 Days			
Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Resul	
114.2-55	Girls lav near rm 114	S	11:07	NA NA		1	
114.2-56	Girls lav near rm 114	S	11:07	NA		-	
114.2-57	Bubbler near rm 114	В	11:08	NA		 	
114.2-58	rm 109	S	11:11	NA			
114.2-59	rm 106 B	S	11:13	NA		+	
114.2-60	rm 106C	S	11:13	NA		+	
114.2-61	rm 106A	S	11:13	NA	·		
114.2-62	rm 106A	M	11:13	NA		1	
114.2-63	rm 106A	S	11:13	NA NA		 	
114.2-64	rm 106A	S	1:19:00 AM11:1:	NA			
114.2-65	rm 104	s	11:19	NA NA		+	
114.2-66	Bubbler near rm 104	В	11:20	NA			
114.2-67	Women's rm	S	11:21	NA		-	
114.2-68	Men's m	S	11:22	NA		 	
114.2-69	rm 165	S	11:23	NA		+	
114.2-70	rm 165	S	11:23	NA NA		 	
114.2-71	rm 161	S	11:25	NA		 	
114.2-72	rm 161	S	11:25.	NA NA		+	

Sampled By: John Robinson Print Name Stohl Env: John Robinson Date: 10/4/2016 Relinquished By: Print Name Stohl Env: Joseph Mecca Date: 10/5/2016 Received (Name / Lab): Date: Sample Login (Name / Lab): Date: Time: Analysis (Name / Lab): Date: QA/QC Review (Name / Lab): Date: Time: Archived / Released: QA/QC InterLAB Use: Date: Time:

Page

4 of 9



Submitted to: (Lab Name)

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES

1169 ALIENDALE PKWY. BUFFALO, NEW YORK 14219

(716) 312-8092

WWW.stohlenvironmental.com

Client: Frontier CSD

Contact: Bob Markel

Building: Frontier Middle School

Location: 4432 Bayview Rd, Hamburg, NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9

X

5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
114.2-73	rm 161	S	11:25	NA.		-
114.2-74	rm 161	S	11:25	NA NA		
114.2-75	rm 161	S	11:25	NA NA		
114.2-76	rm 161	S	11:25	NA		· ·
114.2-77	rm 159	S	11:29	NA	· · · · · · · · · · · · · · · · · · ·	1
114.2-78	rm 159	S	11:29	NA		-
114.2-79	rm 159	S	11:29	NA .		1
114.2-80	rm 159	S	11:29	NA NA		
114.2-81	rm 159	S	11:29	NA NA		
114.2-82	rm 159	S	11:29	NA NA		· · · · · · · · · · · · · · · · · · ·
114.2-83	Boys lav across from rm 155	S	11:33	NA NA		
114.2-84	Boys lav across from rm 155	S	11:33	NA NA		1
114.2-85	Boys lav across from rm 155	S	11:33	NA NA		
114.2-86	Boys lav across from rm 155	S	11:33	. NA		<u> </u>
114.2-87	Drinking fountain	DF	11:34	Emabf8_1c		-
114.2-88	Bubbler	В	11:37	NA NA		
114.2-89	Girls lav across from rm 150B	S	11:38	NA NA		
114.2-90	Girts lav across from rm 150B	s	11:38	NA NA		+

Please e-mail lab results to labs	@stohlenv.com	•	
Sampled By: John Robinso		Stohl Env: John Robinson	Date: 10/4/2016
Relinquished By:	Print Name	Stohl Env: Joseph Mecca	Date: 10/5/2016
Received (Name / Lab):	<u> </u>	Date:	Time:
Sample Login (Name / Lab):		Date:	Time:
Analysis (Name / Lab):		Date:	Time:
QA/QC Review (Name):		Date:	Time:
Archived / Released:	QA/QC InterLAB Use:	Date:	Time:

Page



Submitted to: (Lab Name)

Schneider

ENVIRON	## IALLENDALE PROME TO FIRE STORM GROUP OF COMPANIES # (716) 312-0070 图 (716) 312-8092 www.stohlenvironmental.com		STOHL Job #	2016L-114.2	_
Client:	Frontier CSD	Contact: Bot) Markel		
Building:	Frontier Middle School	Location: 443	2 Bayview Rd, Hamburg, N	IY .	_
LEAD Water by	AAS-GF: ASTM D3559-03D, US EPA 200.9	X	Turnard 5 Days	•	
		:			

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
114.2-91	Girls lav across from rm 150B	S	11:38	NA NA		
114.2-92	Girls lav across from rm 150B	\$	11:38	NA NA		1
114.2-93	rm 141	S	11:42	NA NA		<u> </u>
114.2-94	rm 141	S	11:42	. NA		
114.2-95	rm 141	S	11:42	NA NA		
114.2-96	rm 142	S	11:46	NA NA		
114.2-97	rm 142	S	11:46	NA NA		
114.2-98	rm 142	S	11:46	NA NA		
114.2-99	Boys locker rm	В	11:49	NA NA		-}
114.2-100	Boys locker rm	В	11:49	NA NA	· · · · · · · · · · · · · · · · · · ·	
114.2-101	Boys locker rm	S	11:49	NA		-
114.2-102	Football locker rm	В	11:52	NA NA		
114.2-103	Football locker rm	S	11:52	NA.		
114.2-104	rm 145	s	11:53	NA NA		
114.2-105	rm 148	S	11:55	NA NA		
114.2-106	rm 149B	S	11:57	NA NA	· · · · ·	
114.2-107	Bubbler	В	11:58	NA	·	
114.2-108	rm 149A	S	11:59	NA		

Notes: Please e-mail lab results to lab	s@stohlenv.com		
Sampled By: John Robins	on Print Name	Stohl Env: John Robinson	Date: 10/4/2016
Relinquished By:	Print Name	Stohi Env: Joseph Mecca	Date: 10/5/2016
Received (Name / Lab):	<u> </u>	Date:	Time:
Sample Login (Name / Lab):		Date:	Time:
Analysis (Name / Lab):		Date:	Time:
QA/QC Review (Name / Lab):		Date:	Time:
Archived / Released:	QA/QC InterLAB Use:	Date:	Time:



Submitted to: (Lab Name) Schneider ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES STOHL Job # 2016L-114.2 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219

\$\((716)\) 312-6070 \(\frac{1}{2}\) 4716\) 312-6092

www.stohlenvironmental.com Contact: Bob Markel Client: Frontier CSD Building: Frontier Middle School Location: 4432 Bayview Rd, Hamburg, NY Turnaround LEAD Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 Х 5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
114.2-109	rm 137	S	12:00	NA NA		
114.2-110	rm 137	S	12:00	NA		
114.2-111	rm 137	S	12:00	NA NA		
114.2-112	rm 135	S	12:03	NA		
114.2-113	rm 135	S	12:03	NA NA		
114.2-114	rm 135	S	12:03	NA NA		
114.2-115	rm 135	S	12:03	NA .		
114.2-116	rm 133	S	12:04	NA		
114.2-117	rm 134	В	12:06	NA	•	
114.2-118	rm 134	S	12:06	NA		
114.2-119	rm 134	S	12:06	NA		
114.2-120	rm 131	S	12:11	NA		
114.2-121	rm 131	S	12:11	NA -		
114.2-122	rm 131	S	12:11	NA		
114.2-123	rm 131	S	12:11	NA		
114.2-124	rm 131	S	12:11	NA		
114.2-125	rm 131	S	12:11	NA NA		
114.2-126	rm 127	S	12:16	NA		

Notes: Please e-mail lab results to labs@	estonlenv.com				
Sampled By: John Robinson	Print Name	Stohl Env: John Robinson	Date: 10/4/2016		
Relinquished By:	Print Name	Stohl Env: Joseph Mecca	Date: 10/5/2016		
Received (Name / Lab):		Date:	Time:		
Sample Login (Name / Lab):		Date:	Time:		
Analysis (Name / Lab):		Date:	Time:		
QA/QC Review (Name / Lab):		Date:	Time:		
Archived / Released:C	NA/QC InterLAB Use:	Date:	Time:		



Submitted to: (Lab Name)

Schneider

ENVIRONMENTAL CONSULTANTS . A MEMBER OF THE STOHL GROUP OF COMPANIES 4169 ALLENDALE PKWY: BUFFALO, NEW YORK 14219

2 (716) 312-0070 **1** (716) 312-8092 www.stohlenvironmental.com

Relinquished By:

Received (Name / Lab):

Analysis (Name / Lab):

Archived / Released:

Sample Login (Name / Lab):

QA/QC Review (Name / Lab):

STOHL Job # 2016L-114.2

ASTM D3559-03D, US E	PA 200.9	x	Turnaround 5 Days		
			:		
Location	Outlet Type	Time	Cooler Model	Lab ID	Resul
rm 166	S	12:17	NA		1
rm 166	s	12:17	NA ·		1
rm 166	S	12:17	. NA		1
Drinking fountain	DF	12:19	NA		1
Drinking fountain	DF	12:19	NA		1
rm 167	S	12:21	NA		1
rm 167	s	12:21	. NA		1
rm 167	S	12:21	NA		T
rm 172	S	12:23	NA	,	
rm 168	s	12:24	NA		İ
rm 126	s	12:26	NA		
rm 122	IM	12:28	NA.		
Kitchen	S	12:30	NA		ĺ
Kitchen	s	12:30	NA NA		
Kitchen	s	12:30	NA.	*	1
Kitchen	S	12:30	NA		
Kitchen	S	12:30	NA		<u> </u>
Kitchen	s	12:30	NA		İ .
	Location rm 166 rm 166 rm 166 Drinking fountain Drinking fountain rm 167 rm 167 rm 167 rm 168 rm 126 rm 122 Kitchen Kitchen Kitchen Kitchen	rm 166 S rm 166 S rm 166 S Drinking fountain DF Drinking fountain DF rm 167 S rm 167 S rm 172 S rm 168 S rm 126 S rm 122 IM Kitchen S Kitchen S	Location Outlet Type Time rm 166 S 12:17 rm 166 S 12:17 rm 166 S 12:17 Drinking fountain DF 12:19 Drinking fountain DF 12:19 rm 167 S 12:21 rm 167 S 12:21 rm 167 S 12:21 rm 172 S 12:23 rm 168 S 12:24 rm 126 S 12:26 rm 122 IM 12:28 Kitchen S 12:30 Kitchen S 12:30 Kitchen S 12:30 Kitchen S 12:30 Kitchen S 12:30	Location Outlet Type Time Cooler Model	Location Outlet Type Time Time NA Lab ID

Stohl Env:

Date:

Date:

Date:

Date:

Date:

Joseph Mecca

Date: 10/5/2016

8 of 9

Print Name

QA/QC InterLAB Use:



Submitted to: (Lab Name)

Contact: Bob Markel

Schneider

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES 4169 ALLENDALE PKWY: BUFFALO, NRW YORK 14219

(716) 312-8970 E (716) 312-8992

www.stohlenvironmental.com

Client:

Frontier CSD

STOHL Job # 2016L-114.2

Building: Frontie	er Middle School	<u> </u>	Location	: 4432 Bayview Rd,	Hamburg,	NY .	
LEAD Water by AAS-GF	F: ASTM D3559-03D, US EPA	A 200.9	X Turnaround 5 Days			4.4	
		· · · · · · · · · · · · · · · · · · ·					,
Sample #	Location	Outlet Type	Time	Cooler Mode	el [Lab ID	Results
114.2-145	Kitchen	S	12:30	NA NA		•	
114.2-146	Kitchen	S	12:30	NA			<u> </u>
114.2-147	Kitchen	S	12:30	NA NA			
114.2-148	rm 116d	S	12:36	NA			
114.2-149	Basement sink	S	12:40	. NA			
			·				
					L		
		<u> </u>					
		<u> </u>					
•					L		
	4.						
					L		
Notes: Please e-mail lab	results to labs@stohlenv.con	1					
Sampled By:	John Robinson	Print Name	Stohi Env:	John Robinson	_ Date: <u>1</u>	0/4/2016	
Relinquished By:	- Committee - Comm	Print Name	Stohl Env:	Joseph Mecca	Date: <u>1</u>	0/5/2016	
Received (Name /	/ Lab):		Date:	· · · · · · · · · · · · · · · · · · ·	Time: _	· .	
Sample Login (Na	me / Lab):		Date:	· ·	Time: _		
Analysis (Name / I	Lab):		Date:		Time: _		
QA/QC Review (N	lame / Lab):		Date:		Time: _		
Archived / Release	ed:QA/QC InterLA	AB Use:	Date:		Time: _		
				*			