

November 4, 2016

Mr. Robert Markel Frontier Central School District Building Department 5120 Orchard Avenue Hamburg, New York 14075

RE: Investigation and Sampling of Drinking Water for Lead Concentrations

Dear Mr. Markel:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the Frontier Central School District, including:

Pinehurst Elementary School, 6050 Fairway Court Lakeview, New York.

This report is prepared to assist the District in complying with the requirements of NYS regulations, SUBPART 67-4: Lead Testing in School Drinking Water, by identifying the sources of potable water with lead concentrations greater than or equal to the NYS "Action Level of 15 parts per billion (ppb)".

The Investigation and Sampling was performed on September 26, 2016. The Protocol for the Investigation followed the requirements of NYS regulations as well as USEPA Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 (Executive Summary) of the accompanying report, based upon the sampling and analysis performed, 12 sources of potable water in the Pinehurst Elementary School have been identified as having lead concentrations in water above the NYS Action Level of 15 parts per billion. To comply with NYS regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to Frontier Central School District.

Sincerely, Stohl Environmental, LLC.

William K. Sisco Senior Project Manager

Willufre

Investigation and Sampling Of Sources of Potable Water For Lead Concentrations

Prepared for:

Mr. Robert Markel
Frontier Central School District
Building Department
5120 Orchard Avenue
Hamburg, New York 14075

Prepared by:



ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES

Conditions as of September 26, 2016



Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports by Building
- 1.5. Laboratory Certifications
- 1.6. Chains of Custody



1.1 Sampling Protocol and Summary of Results:

Stohl Environmental was retained by Frontier Central School District to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

• Pinehurst Elementary School, 6050 Fairway Court Lakeview, New York.

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from all outlets in Pinehurst Elementary School. Outlets are defined in NYS regulations as: "a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets".

Sampling Protocol:

In accordance with NYS regulations, **Subpart 67-4: Lead Testing in School Drinking Water**, and the EPA guidance document, **'3Ts for Reducing Lead in Drinking Water in Schools"**, Stohl Environmental's protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- Service Connection Sampling: Samples were collected at the service connection as follows:
 - Service Connection Sample: As detailed in EPA guidance documents, this sample is not a first-draw sample. The cold water tap closest to the service connection was opened, and the sample was collected immediately after a change in water temperature was detected, or after 30 seconds.
 - Water Main Sample: This sample was collected at the same location as the Service Connection sample; however, it was collected after water was allowed to run an additional 3 minutes after the temperature change, but not more than 3 minutes and 30 seconds.

Stohl File #: 2016L-114

Laboratory Analysis: Samples were submitted following strict chain-of-custody protocols
to an independent laboratory approved by the NYS Department of Health's Environmental
Laboratory Approval Program (ELAP).



1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building	Date of	Total	First Drav	v Samples	Confirmator	y Samples **
Name	Sample Event	Number Samples Collected	Number of Samples Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb	Number of Samples Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
Pinehurst Elementary School	9/26/2016	120	108	12	0	0

^{**} Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

Listing of Outlets Requiring Remediation

Locations	of Outlets Analyz	ed above the NYS Action Level	of 15 parts per billion	on based upon
Analysis o	f First Draw Sam	oles and Confirmatory Samples		
Sample #	Sample Type	Classroom or other Location	Fixture/Outlet type	Laboratory
				Analysis in
				ppb
114.6-33	First Draw	Classroom 133	Bubbler	16.7
114.6-35	First Draw	Classroom 133 Janitor's Sink	Sink	27.7
114.6-40	First Draw	Classroom 131	Bubbler	23.3
114.6-50	First Draw	Classroom 136 Bathroom Sink	Sink	17.4
114.6-63	First Draw	Classroom 138 Bathroom Sink	Sink	16.3
114.6-66	First Draw	Classroom 139A Sink	Sink	55.1
114.6-80	First Draw	Classroom 148 Sink	Sink	16.2
114.6-87	First Draw	Classroom 154 Sink	Sink	25.1
114.6-90	First Draw	Classroom 125 Office	Sink	18.8
		Bathroom Sink		
114.6-117	Water Main	Water Main Flush		324
	Flush			
114.6-118	Water Main	Water Main Flush Temperature		127
	Flush	Change		
	Temperature			
	Change			
114.6-120	First Draw	Outside Room 104 Hose Bib	Hose Bib	23.3

Stohl File #: 2016L-114



A MEMBER OF THE STOHL GROUP OF COMPANIES

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration in excess of the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.



1.4 Laboratory Analytical Reports by Building

SLGi* Ar

Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)

Address: 4169 Allendale Parkway

Blasdell, NY 14219

Attn:

Project: Pinehurst Elem.

Location: 6050 Fairway Ct Lakeview, NY

Number: 2016L-114.6

Order #: 186524

MatrixDrinking WaterReceived09/29/16

Reported 09/29/16

PO Number:

Sample ID	Cust. Sample ID	Location Method	Decell	DI +	11-16-	Australia Barr	A I 1
Parameter			Result	RL*	Units	Analysis Date	Anaiyst
186524-001	114.6-01	112 S					
<i>Metals An</i> Lead	aiysis	EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/20/16	SA
	444000		<5.00	5.00	μg/L	10/20/16	SA
186524-002	114.6-02	111 S					
<i>Metals An</i> Lead	aiysis	EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/20/16	SA
	4440.00		<5.00	5.00	μg/L	10/20/10	SA
186524-003	114.6-03	113 S					
<i>Metals An</i> Lead	aiysis	EPA 200.9 Rev 2.2	5.92	5.00	μg/L	10/20/16	SA
	444004		5.92	5.00	μg/L	10/20/10	SA
186524-004	114.6-04	110 S					
<i>Metals An</i> Lead	aiysis	EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/20/16	SA
	4440.05		<5.00	5.00	μg/L	10/20/10	SA
186524-005	114.6-05	114 S					
<i>Metals An</i> Lead	alysis	EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/20/16	SA
			<5.00	5.00	μg/L	10/20/16	SA
186524-006	114.6-06	109 S					
<i>Metals An</i> Lead	aiysis	EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/20/16	SA
			<5.00	5.00	μg/L	10/20/16	SA
186524-007	114.6-07	115 S					
<i>Metals An</i> Lead	aiysis	EPA 200.9 Rev 2.2	<5.00	5.00	ua/l	10/20/16	SA
			<5.00	5.00	μg/L	10/20/16	SA
186524-008	114.6-08	108 S					
<i>Metals An</i> Lead	aiysis	EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/20/16	SA
	444000		<5.00	5.00	μg/L	10/20/10	SA
186524-009	114.6-09	116BR S					
<i>Metals An</i> Lead	aıysıs	EPA 200.9 Rev 2.2	<5.00	5.00	ua/l	10/20/16	SA
			<0.00	5.00	μg/L	10/20/10	ЭА
186524-010	114.6-10	116BR S					
Metals An	aıysıs	EDA 200 0 Pov 2 2	<5.00	5.00	ug/l	10/20/16	SA
Lead		EPA 200.9 Rev 2.2	<0.00	5.00	μg/L	10/20/16	SA
186524-011	114.6-11	117BR S					
Metals An	alysis	EDA 200 0 Day 2 0	.5.00	F 00	/1	40/00/46	C 4
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/20/16	SA

Report Amended. Removed samples 114.6-121 through 114.6-137 from report due to not being collected.

SLGi*

Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)

Address: 4169 Allendale Parkway

Blasdell, NY 14219

Attn:

Project: Pinehurst Elem.

Location: 6050 Fairway Ct Lakeview, NY

Number: 2016L-114.6

Order #: 186524

Matrix Drinking Water

Received 09/29/16 **Reported** 11/04/16

PO Number:

			-				
Sample ID	Cust. Sample ID	Location					
Parameter		Method	Result	RL*	Units	Analysis Date	Analys
186524-012	114.6-12	117BR S					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/20/16	SA
186524-013	114.6-13	117Jan S					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/20/16	SA
186524-014	114.6-14	107 S					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/20/16	SA
186524-015	114.6-15	118 S					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/20/16	SA
186524-016	114.6-16	106 S					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/20/16	SA
186524-017	114.6-17	119 S					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/20/16	SA
186524-018	114.6-18	105 S					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/20/16	SA
186524-019	114.6-19	120 S					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/20/16	SA
186524-020	114.6-20	104 S					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/20/16	SA
186524-021	114.6-21	121 S					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-022	114.6-22	100BR S					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA

Report Amended. Removed samples 114.6-121 through 114.6-137 from report due to not being collected.

SLGi*

Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)

Address: 4169 Allendale Parkway

Blasdell, NY 14219

Attn:

Project: Pinehurst Elem.

Location: 6050 Fairway Ct Lakeview, NY

Number: 2016L-114.6

Order #: 186524

MatrixDrinking WaterReceived09/29/16

Received 09/29/16 **Reported** 11/04/16

PO Number:

Sample ID Cu	ust. Sample ID	Location Method	Result	RL*	Units	Analysis Date	Analyst
	114.6-23	124 DF	Result	NL .	Ullits	Analysis Date	Allalyst
186524-023 Metals Analys		124 DF					
Lead	113	EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-024	114.6-24	124 S					
Metals Analys	is						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-025	114.6-25	124 S					
Metals Analys	is						
Lead		EPA 200.9 Rev 2.2	8.08	5.00	μg/L	10/24/16	SA
186524-026	114.6-26	124 S					
Metals Analys	sis						
Lead		EPA 200.9 Rev 2.2	8.25	5.00	μg/L	10/24/16	SA
186524-027	114.6-27	101BR S					
Metals Analys	sis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-028	114.6-28	101 S					
Metals Analys	sis						
Lead		EPA 200.9 Rev 2.2	10.8	5.00	μg/L	10/24/16	SA
186524-029	114.6-29	132 S					
Metals Analys	sis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-030	114.6-30	132 B					
Metals Analys	sis						
Lead		EPA 200.9 Rev 2.2	5.14	5.00	μg/L	10/24/16	SA
186524-031	114.6-31	132 S					
Metals Analys	sis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-032	114.6-32	133 S					
Metals Analys	sis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-033	114.6-33	133 B					
Metals Analys	sis						
Lead		EPA 200.9 Rev 2.2	16.7	5.00	μg/L	10/24/16	SA

Report Amended. Removed samples 114.6-121 through 114.6-137 from report due to not being collected.

Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)

Address: 4169 Allendale Parkway

Blasdell, NY 14219

Attn:

Project: Pinehurst Elem.

Location: 6050 Fairway Ct Lakeview, NY

Number: 2016L-114.6

Order #: 186524

Matrix Drinking Water
Received 09/29/16
Reported 11/04/16

PO Number:

Sample ID	Cust. Sample ID	Location	Decell	DI.*	11-16-	Australia Barr	A I 1
Parameter		Method	Result	RL*	Units	Analysis Date	Anaiyst
186524-034	114.6-34	133 S					
Metals And Lead	alysis	EPA 200.9 Rev 2.2	<5.00	5.00	a/l	10/24/16	SA
			<5.00	5.00	μg/L	10/24/16	SA
186524-035	114.6-35	133Jan S					
Metals And Lead	aiysis	EPA 200.9 Rev 2.2	27.7	5.00	/	10/24/16	SA
			21.1	5.00	μg/L	10/24/16	SA
186524-036	114.6-36	134 S					
Metals And Lead	aiysis	EPA 200.9 Rev 2.2	<5.00	5.00	/	10/24/16	SA
			<5.00	5.00	μg/L	10/24/16	SA
186524-037	114.6-37	134 B					
Metals And Lead	alysis	EPA 200.9 Rev 2.2	<5.00	5.00	/	10/24/16	SA
			<5.00	5.00	μg/L	10/24/16	SA
186524-038	114.6-38	134 S					
Metals And Lead	alysis	EPA 200.9 Rev 2.2	<5.00	5.00	/	10/24/16	SA
			<5.00	5.00	μg/L	10/24/16	SA
186524-039	114.6-39	131 S					
Metals And	alysis	EDA 200 0 Dov 2.2	0.54	F 00	/1	10/24/16	C A
Lead		EPA 200.9 Rev 2.2	9.54	5.00	μg/L	10/24/16	SA
186524-040	114.6-40	131 B					
Metals And	alysis	EDA 000 0 D 0 0		5.00		40/04/40	0.4
Lead		EPA 200.9 Rev 2.2	23.3	5.00	μg/L	10/24/16	SA
186524-041	114.6-41	131 S					
Metals An	alysis	EDA 000 0 D 0 0		5 00		10/01/10	0.4
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-042	114.6-42	135 S					
Metals An	alysis	EDA 000 0 D 0 0	5.00	5 .00		40/04/40	0.4
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-043	114.6-43	135 B					
Metals An	alysis	EDA 000 0 D 0 0	5.00	5 .00		40/04/40	0.4
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-044	114.6-44	135 S					
Metals And	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA

Report Amended. Removed samples 114.6-121 through 114.6-137 from report due to not being collected.

Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)

Address: 4169 Allendale Parkway

Blasdell, NY 14219

Attn:

Project: Pinehurst Elem.

Location: 6050 Fairway Ct Lakeview, NY

Number: 2016L-114.6

Order #:

186524

Matrix Received Reported Drinking Water 09/29/16

11/04/16

PO Number:

Sample ID	Cust. Sample ID	Location	-	51.4			
Parameter		Method	Result	RL*	Units	Analysis Date	Analyst
186524-045	114.6-45	130 S					
Metals An	alysis	FDA 200 0 Day 2 0	5.00	5.00	/1	40/04/40	C 4
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-046	114.6-46	130 B					
Metals An	alysis	EDA 200 0 Day 2 0	5.00	F 00	//	40/04/40	C 4
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-047	114.6-47	130 S					
Metals An	alysis	EBA 000 0 B 0 0		5 00		10/01/10	0.4
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-048	114.6-48	136 S					
Metals An	alysis	-D					
Lead		EPA 200.9 Rev 2.2	5.18	5.00	μg/L	10/24/16	SA
186524-049	114.6-49	136 B					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-050	114.6-50	136 S					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	17.4	5.00	μg/L	10/24/16	SA
186524-051	114.6-51	129 S					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-052	114.6-52	129 B					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-053	114.6-53	129 S					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-054	114.6-54	129 S					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-055	114.6-55	137 B					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA

Report Amended. Removed samples 114.6-121 through 114.6-137 from report due to not being collected.

Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)

Address: 4169 Allendale Parkway

Blasdell, NY 14219

Attn:

Project: Pinehurst Elem.

Location: 6050 Fairway Ct Lakeview, NY

Number: 2016L-114.6

Order #: 186524

Matrix Drinking Water
Received 09/29/16
Reported 11/04/16

PO Number:

Sample ID	Cust. Sample ID	Location	Dorosti	DI +	11-16-	Aughoria Data	A I 1
Parameter		Method	Result	RL*	Units	Analysis Date	Anaiyst
186524-056	114.6-56	137 S					
Metals And Lead	alysis	EPA 200.9 Rev 2.2	5.27	5.00	/1	10/24/16	SA
			5.27	5.00	μg/L	10/24/16	SA
186524-057	114.6-57	128 S					
Metals And Lead	aiysis	EPA 200.9 Rev 2.2	5.42	5.00	/	10/24/16	SA
			5.42	5.00	μg/L	10/24/16	SA
186524-058	114.6-58	128 B					
Metals And Lead	aiysis	EPA 200.9 Rev 2.2	<5.00	5.00	/	10/24/16	SA
			<5.00	5.00	μg/L	10/24/16	SA
186524-059	114.6-59	128 S					
Metals And Lead	alysis	EPA 200.9 Rev 2.2	<5.00	5.00	/	10/24/16	SA
			<5.00	5.00	μg/L	10/24/16	SA
186524-060	114.6-60	127 S					
Metals And Lead	alysis	EPA 200.9 Rev 2.2	<5.00	5.00	/	10/24/16	SA
			<5.00	5.00	μg/L	10/24/16	SA
186524-061	114.6-61	127 B					
Metals And Lead	alysis	EPA 200.9 Rev 2.2	6.32	5.00	ua/l	10/24/16	SA
			0.32	5.00	μg/L	10/24/16	SA
186524-062	114.6-62	127 S					
Metals And Lead	aiysis	EPA 200.9 Rev 2.2	.F.00	5.00	/	10/24/16	SA
			<5.00	5.00	μg/L	10/24/16	SA
186524-063	114.6-63	138BR S					
Metals And Lead	alysis	EPA 200.9 Rev 2.2	40.0	5.00	/1	10/24/16	SA
			16.3	5.00	μg/L	10/24/16	SA
186524-064	114.6-64	140Jan S					
Metals And	alysis	EDA 200 0 Day 0 0	.F.00	F 00	/1	40/04/40	C 4
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-065	114.6-65	140BR S					
Metals And	alysis	EDA 200 0 D 0 0	0.00	F 00	/!	40/04/40	C A
Lead		EPA 200.9 Rev 2.2	9.23	5.00	μg/L	10/24/16	SA
186524-066	114.6-66	139A S					
Metals And	alysis	EDA 000 0 D 000		05.0		40/04/40	0.4
Lead		EPA 200.9 Rev 2.2	55.1	25.0	μg/L	10/24/16	SA

Report Amended. Removed samples 114.6-121 through 114.6-137 from report due to not being collected.

Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)

Address: 4169 Allendale Parkway

Blasdell, NY 14219

Attn:

Project: Pinehurst Elem.

Location: 6050 Fairway Ct Lakeview, NY

Number: 2016L-114.6

Order #: 186524

MatrixDrinking WaterReceived09/29/16

Received 09/29/16 **Reported** 11/04/16

PO Number:

Sample ID Parameter	Cust. Sample ID	Location Method	Result	RL*	Units	Analysis Data	Analyset
	1116 67		Result	RL .	Ullits	Analysis Date	AllalySt
186524-067 <i>Metals An</i>	114.6-67	141BR S					
Lead	aiysis	EPA 200.9 Rev 2.2	5.39	5.00	μg/L	10/24/16	SA
186524-068	114.6-68	141 S					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-069	114.6-69	141BR S					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-070	114.6-70	143 S					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-071	114.6-71	143 S					
Metals An	alysis	EBA 000 0 B 0 0		5 .00	4	10/04/10	0.4
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-072	114.6-72	143 S					
Metals And	alysis	FDA 200 0 Day 2 0	5.00	F 00	/1	40/04/40	C 4
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-073	114.6-73	143A S					
Metals And	alysis	EDA 200 0 Day 2 0		F 00	/1	40/04/40	C 4
Lead		EPA 200.9 Rev 2.2	5.54	5.00	μg/L	10/24/16	SA
186524-074	114.6-74	143A S					
<i>Metals An</i> Lead	aiysis	EPA 200.9 Rev 2.2	7.45	5.00	μg/L	10/24/16	SA
	4440.75		7.45	5.00	µg/L	10/24/10	SA
186524-075	114.6-75	143A S					
Metals And Lead	aiysis	EPA 200.9 Rev 2.2	5.13	5.00	μg/L	10/24/16	SA
	114.6-76	143A S	0.10	0.00	μg/ <u>-</u>	10/24/10	5 / (
186524-076 <i>Metals An</i>		143A 3					
Lead	aiyəiə	EPA 200.9 Rev 2.2	12.3	5.00	μg/L	10/24/16	SA
186524-077	114.6-77	144 S			F 3-		-
Metals And		177 0					
Lead	, s.c	EPA 200.9 Rev 2.2	11.7	5.00	μg/L	10/24/16	SA

Report Amended. Removed samples 114.6-121 through 114.6-137 from report due to not being collected.

SLGi*

Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)

Address: 4169 Allendale Parkway

Blasdell, NY 14219

Attn:

Project: Pinehurst Elem.

Location: 6050 Fairway Ct Lakeview, NY

LNumber: 2016L-114.6

Order #: 186524

Matrix Drinking Water

Received 09/29/16 **Reported** 11/04/16

PO Number:

Sample ID Parameter	Cust. Sample ID	Location Method	Result	RL*	Units	Analysis Date	Analyst
186524-078	114.6-78	145Jan S				<u> </u>	
Metals And Lead	alysis	EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-079	114.6-79	146 S					
Metals And Lead	alysis	EPA 200.9 Rev 2.2	13.6	5.00	μg/L	10/24/16	SA
186524-080	114.6-80	148 S					
<i>Metals And</i> Lead	alysis	EPA 200.9 Rev 2.2	16.2	5.00	μg/L	10/24/16	SA
186524-081	114.6-81	149 S					
<i>Metals And</i> Lead	alysis	EPA 200.9 Rev 2.2	8.32	5.00	μg/L	10/24/16	SA
186524-082	114.6-82	CO 149 DF					
<i>Metals And</i> Lead	alysis	EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-083	114.6-83	150 S					
<i>Metals And</i> Lead	alysis	EPA 200.9 Rev 2.2	9.15	5.00	μg/L	10/24/16	SA
186524-084	114.6-84	151 S					
<i>Metals And</i> Lead	alysis	EPA 200.9 Rev 2.2	11.7	5.00	μg/L	10/24/16	SA
186524-085	114.6-85	152 S					
<i>Metals And</i> Lead	alysis	EPA 200.9 Rev 2.2	9.34	5.00	μg/L	10/24/16	SA
186524-086	114.6-86	CO 154 DF					
<i>Metals And</i> Lead	alysis	EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-087	114.6-87	154 S					
<i>Metals And</i> Lead	alysis	EPA 200.9 Rev 2.2	25.1	5.00	μg/L	10/24/16	SA
186524-088	114.6-88	CO 126 DF					
Metals And Lead	alysis	EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA

Report Amended. Removed samples 114.6-121 through 114.6-137 from report due to not being collected.

SLG**i***

Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)

Address: 4169 Allendale Parkway

Blasdell, NY 14219

Attn:

Project: Pinehurst Elem.

Location: 6050 Fairway Ct Lakeview, NY

Number: 2016L-114.6

Order #: 186524

Matrix Drinking Water
Received 09/29/16
Reported 11/04/16

PO Number:

Sample ID	Cust. Sample ID	Location					
Parameter		Method	Result	RL*	Units	Analysis Date	Analyst
186524-089	114.6-89	125 DF					
Metals And	alysis	-D.					
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-090	114.6-90	125 S					
Metals And	alysis	EBA 000 0 B 0 0		5 00	4	10/01/10	0.4
Lead		EPA 200.9 Rev 2.2	18.8	5.00	μg/L	10/24/16	SA
186524-091	114.6-91	125 S					
Metals And	alysis	EBA 000 0 B 0 0		5 00	4	10/01/10	0.4
Lead		EPA 200.9 Rev 2.2	7.82	5.00	μg/L	10/24/16	SA
186524-092	114.6-92	125 S					
Metals And	alysis	EBA 000 0 B 0 0		5 00	4	10/01/10	0.4
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-093	114.6-93	125 S					
Metals And	alysis	EBA 000 0 B 0 0		5 00	4	10/01/10	0.4
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-094	114.6-94	157BR S					
Metals And	alysis	EBA 000 0 B 0 0		5 00	4	10/01/10	0.4
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-095	114.6-95	157BR S					
Metals And	alysis	EDA 000 0 D 0 0		5 00	4	10/01/10	0.4
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-096	114.6-96	157Jan S					
Metals And	alysis	EDA 000 0 D 0 0	5 00	5.00		40/04/40	0.4
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-097	114.6-97	123Jan S					
Metals And	alysis	EDA 000 0 D 0 0	.5.00	F 00		40/04/40	C 4
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-098	114.6-98	123BR S					
Metals And	alysis	EDA 000 0 D 0 0	.5.00	F 00	/!	40/04/40	0.4
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-099	114.6-99	123BR S					
Metals And	alysis	EDA 000 0 D 0 0	.5.00	F 00	/!	40/04/40	C 4
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA

Report Amended. Removed samples 114.6-121 through 114.6-137 from report due to not being collected.

SLGi"

Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)

Address: 4169 Allendale Parkway

Blasdell, NY 14219

Attn:

Project: Pinehurst Elem.

Location: 6050 Fairway Ct Lakeview, NY

Number: 2016L-114.6

Order #: 186524

Matrix Drinking Water
Received 09/29/16

Reported 11/04/16

PO Number:

Sample ID	Cust. Sample ID	Location					
Parameter		Method	Result	RL*	Units	Analysis Date	Analyst
186524-100	114.6-100	158 S					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	6.32	5.00	μg/L	10/24/16	SA
186524-101	114.6-101	158 S					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	5.21	5.00	μg/L	10/24/16	SA
186524-102	114.6-102	160BR S					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-103	114.6-103	163 S					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-104	114.6-104	163 S					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-105	114.6-105	163 S					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	8.71	5.00	μg/L	10/24/16	SA
186524-106	114.6-106	163 S					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-107	114.6-107	163 S					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-108	114.6-108	163 S					
Metals An	alysis						
Lead	•	EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-109	114.6-109	163 Cook Vessel					
Metals An	alysis						
Lead	-	EPA 200.9 Rev 2.2	11.2	5.00	μg/L	10/24/16	SA
186524-110	114.6-110	163 S					
Metals An	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA

Report Amended. Removed samples 114.6-121 through 114.6-137 from report due to not being collected.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)

Address: 4169 Allendale Parkway

Blasdell, NY 14219

Attn:

Project: Pinehurst Elem.

Location: 6050 Fairway Ct Lakeview, NY

Number: 2016L-114.6

Order #:

186524

Matrix Received Reported Drinking Water

09/29/16 11/04/16

PO Number:

Sample ID	Cust. Sample ID	Location					
Parameter		Method	Result	RL*	Units	Analysis Date	Analyst
186524-111	114.6-111	163 S					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-112	114.6-112	163 S					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-113	114.6-113	163 HB					
Metals Ana	alysis	5D4 000 0 D 0 0		5.00	4	10/01/10	0.4
Lead		EPA 200.9 Rev 2.2	5.12	5.00	μg/L	10/24/16	SA
186524-114	114.6-114	166 S					
<i>Metals Ana</i> Lead	alysis	EPA 200.9 Rev 2.2	-F 00	F 00	/1	10/24/16	SA
			<5.00	5.00	μg/L	10/24/16	SA
186524-115	114.6-115	165BR S					
<i>Metals Ana</i> Lead	alysis	EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
	114.6-116	167 S	\3.00	3.00	μ9/ ⊑	10/24/10	OA .
186524-116 <i>Metals Ana</i>		107 3					
Lead	aiysis	EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-117	114.6-117	165 WMF					
Metals Ana	alysis						
Lead	-	EPA 200.9 Rev 2.2	324	100	μg/L	10/24/16	SA
186524-118	114.6-118	165 WMTC					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	127	50.0	μg/L	10/24/16	SA
186524-119	114.6-119	Outside 154 HB					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	μg/L	10/24/16	SA
186524-120	114.6-120	Outside 104 HB					
Metals Ana	alysis						
Lead		EPA 200.9 Rev 2.2	23.3	5.00	μg/L	10/24/16	SA

Report Amended. Removed samples 114.6-121 through 114.6-137 from report due to not being collected.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)

Address: 4169 Allendale Parkway

Blasdell, NY 14219

Attn:

Project: Pinehurst Elem.

-Location: 6050 Fairway Ct Lakeview, NY

Number: 2016L-114.6 PO Number:

Order #:

Matrix

Received

Reported

Cust. Sample ID Location

Sample ID Result RL* **Parameter** Method Units Analysis Date Analyst

186524-11/04/16 12:53 PM

Reviewed By: Ellen Mcdonald **EPA Regulatory Limits**

Project Manager

186524

09/29/16

11/04/16

Drinking Water

Reg. Limit Unit Parameter μg/L 15.0 Lead

Certifications

Parameter	Method	Matrix	CA	СТ	FL	NJ	NY	RI	VA
Lead	EPA 200.9 Rev 2.2	Drinking Water	Χ	Χ	Χ	Χ	Χ	Χ	Χ

Key

State	Regulatory Agency - Lab ID	Certificate Number
CA	CA ELAP	2078
CT	CT DPH	PH-0118
FL	FL ELAP	E87828
NJ	NJDEP	NLC160001
NY	NYELAP-11413	55043
RI	RIDOH	LAO00084
VA	Virginia DCLS/DEQ - 460135	8615

^{&#}x27;X' indicates that the analyte is accredited.

If your state is not listed above, call laboratory for accreditation/certification information.

Report Amended. Removed samples 114.6-121 through 114.6-137 from report due to not being collected.



1.5 Laboratory Certifications



Expires 12:01 AM April 01, 2017 Issued September 22, 2016

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. FAYEZ ABOUZAKI SCHNEIDER LABORATORIES GLOBAL, INC. 2512 WEST CARY STREET RICHMOND, VA 23220-5117

NY Lab Id No: 11413

is hereby APPROVED as an Environmental Laboratory in conformance with the National Environmental Laboratory Accreditation Conference Standards (2003) for the category ENVIRONMENTAL ANALYSES POTABLE WATER All approved analytes are listed below:

Metals I

Lead, Total

EPA 200.9 Rev. 2.2



ork Department TATE of Health

Serial No.: 55043

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.





Expires 12:01 AM April 01, 2017 Issued April 01, 2016

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. FAYEZ ABOUZAKI SCHNEIDER LABORATORIES GLOBAL, INC 2512 WEST CARY STREET RICHMOND, VA 23220-5117 NY Lab Id No: 11413

is hereby APPROVED as an Environmental Laboratory in conformance with the National Environmental Laboratory Accreditation Conference Standards (2003) for the category ENVIRONMENTAL ANALYSES NON POTABLE WATER

All approved analytes are listed below:

Metals I

Lead, Total EPA 200.7 Rev. 4.4

EPA 6010C EPA 7000B

EPA 3020A

EPA 200.9 Rev. 2.2

Sample Preparation Methods

EPA 3010A EPA 3005A

Department OF Health

Serial No.: 54667

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.





Expires 12:01 AM April 01, 2017 Issued April 01, 2016

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. FAYEZ ABOUZAKI SCHNEIDER LABORATORIES GLOBAL, INC 2512 WEST CARY STREET RICHMOND, VA 23220-5117

NY Lab Id No: 11413

EPA 8082A

EPA 3050B EPA 3550C EPA 3031

is hereby APPROVED as an Environmental Laboratory in conformance with the National Environmental Laboratory Accreditation Conference Standards (2003) for the category ENVIRONMENTAL ANALYSES SOLID AND HAZARDOUS WASTE All approved analytes are listed below:

Characteristic Testing		Polychlorinated Biphenyls
TCLP	EPA 1311	PCB-1268
Metals I		Sample Preparation Methods
Barium, Total	EPA 6010C	
Cadmium, Total	EPA 6010C	
Chromium, Total	EPA 6010C	' Department
Lead, Total	EPA 6010C	
	EPA 7000B	of Health
Nickel, Total	EPA 6010C	
Silver, Total	EPA 6010C	
Metals II		
Antimony, Total	EPA 6010C	
Arsenic, Total	EPA 6010C	
Chromium VI	EPA 7196A	
Mercury, Total	EPA 7471B	
Selenium, Total	EPA 6010C	
Polychlorinated Biphenyls		
PCB-1016	EPA 8082A	
PCB-1221	EPA 8082A	
PCB-1232	EPA 8082A	
PCB-1242	EPA 8082A	
PCB-1248	EPA 8082A	
PCB-1254	EPA 8082A	
PCB-1260	EPA 8082A	

Serial No.: 54668

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.

EPA 8082A



PCB-1262



Expires 12:01 AM April 01, 2017 Issued April 01, 2016

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. FAYEZ ABOUZAKI SCHNEIDER LABORATORIES GLOBAL, INC 2512 WEST CARY STREET RICHMOND, VA 23220-5117 NY Lab Id No: 11413

is hereby APPROVED as an Environmental Laboratory for the category ENVIRONMENTAL ANALYSES SOLID AND HAZARDOUS WASTE All approved subcategories and/or analytes are listed below:

Miscellaneous

Asbestos in Friable Material

EPA 600/M4/82/020

Asbestos in Non-Friable Material-PLM

Item 198.6 of Manual (NOB by PLM)

Lead in Dust Wipes

EPA 7000B

Lead in Paint

EPA 7000B

EPA 3050B

Sample Preparation Methods

YORK STATE

W_{RK} Department ATE of Health

Serial No.: 54669

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



Expires 12:01 AM April 01, 2017 Issued April 01, 2016

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. FAYEZ ABOUZAKI SCHNEIDER LABORATORIES GLOBAL, INC 2512 WEST CARY STREET RICHMOND. VA 23220-5117 NY Lab Id No: 11413

is hereby APPROVED as an Environmental Laboratory for the category ENVIRONMENTAL ANALYSES AIR AND EMISSIONS
All approved subcategories and/or analytes are listed below:

Metals I

Lead, Total NIOSH 7082

40 CFR PART 50 1984 APP G

Miscellaneous

Fibers NIOSH 7400 A RULES



Department of Health

Serial No.: 54670

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



1.6 Chains of Custody



Chain of Custody Document Submitted to: (Lab Name) Schneider ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
4169 ALLENDALE PKWY. BUEFALO, NEW YORK 14219
27(716),312-0070 (2) (7) (3) 12-8092.

WWW stohlenkinnmental com STOHL Job # 2016L-114.6 Client: Frontier CSD Contact: Bob Markel Building: Pinehurst Elem. Location: 6050 Fairway Ct., Lakeview NY LEAD Turnaround Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
114.6-01	112	S	11:17	0	:	
114.6-02	111	S	11:18	0		
114.6-03	113	S	11:19	0		
114.6-04	. 110	S	11:20	0		ļ
114.6-05	114	S	11:21	0		
114.6-06	109	S	11:22	0		
114.6-07	115	S	11:23	0		
114.6-08	108	S	11:24	0		
114.6-09	116BR	S	11:27	0		
114.6-10	116BR	S	11:27	0		
114.6-11	117BR	S	11:29	0		
114.6-12	117BR	S	11:29	0		
114.6-13	117Jan	S	11:32	0		
114.6-14	107	S	11:34	0		
114.6-15	118	S	11:35	0		
114.6-16	106	S	11:36	0		
114.6-17	119	s	11:37	0		
114.6-18	105	S	11:38	0		

Notes: Please e-mail lab results to labs@stohler	nv.com	ecked, also e-mail results to:	
Sampled By: Mike Irwin	Print Name	Stoni Env: Mike Irwin	Date: 9/26/2016
Relinquished By:	2 Print Name	Stohl Env: Eric Henderson	Jr. Date: 9/27/2016
Received (Name / Lab):		Date:	Time:
Sample Login (Name / Lab):		Date:	Time:
Analysis (Name / Lab):		Date:	Time:
QA/QC Review (Name / Lab):		Date:	Time:
Archived / Released:QA/QC I	nterLAB Use:	Date:	Time:
	Page	1 of 7	



I MEMBER OF THE ST WY: BUFFALO, NEW YO -0070 M (716) 312-801 blenvironmental.com	OHL GROUP OF COMPANIES:				
	2	STOHL Job#		2016L-11	14.6
		Contact:	Bob Markel		
, ,, <u>,,,</u>		Location:	6050 Fairway Ct., Lakeview	NY	
3559-03D US	FPA 200 9	× I			
000 000, 00			5D	ays	-
····				·	
_ocation	Outlet Type	Time	Cooler Model	Lab ID	Results
120	S	11:39	0	10010	resure
104	S	11:50	0		~
121	S	11:41	. 0		
100BR	S	11:43	0		
124	DF	12:03	0		
124	S	12:03	0		
124	S	12:04	0		
124	S	12:04	0		
101BR	S	12:06	0		
101	S	12:07	0		
132	S	12:13	0		
132	В	12:14	0		
132	S	12:15	0		
133	S	12:16	0	:	
133	В	12:16	0		
		12:16	0		
	S	12:17	0		
134	S	12:29	0		
	120 104 121 100BR 124 124 124 124 101BR 101 132 132 132 133 133 133 133 133Jan	120 S 104 S 104 S 121 S 100BR S 124 DF 124 S 124 S 124 S 124 S 125 S 132 S 132 B 132 S 133 S 133 S 133 S 133 S	Location: Cocation	Cocation Outlet Type Time Cooler Model	Location: 6050 Fairway Ct., Lakeview NY

	_			
Sampled By:	Mike Irwin	Print Name	Stohl Env: Mike Irwin	Date: 9/26/2016
Relinquished By:	_E-fflQ	Print Name	Stohl Env: Eric Henderson Jr.	Date: 9/27/2016
Received (Name	/ Lab):		Date:	Time:
Sample Login (Na	ame / Lab):		Date:	Time:
Analysis (Name / I	Lab):		Date:	Time:
QA/QC Review (N	lame / Lab):		Date:	Time:
Archived / Release	ed:QA/QC Inte	rLAB Use:	Date:	Time:



Submitted to: (Lab Name)

Schneider

4	169 ALLENDALE PRWY: BUFFALO, NEW (716) 313-0070 h (716) 312-0 www.stohlenvironmental.com	YCKK 14219 1092		STOHL J	ob#	2016L-1	14.6
Client: Front	ier CSD		Contact	: Bob Markel			· · · · · · · · · · · · · · · · · · ·
	urst Elem.			: 6050 Fairway Ct., L	akeview N	<u> </u>	
LEAD							
	PE: ACTM DOSEO OOD I	IC EDA 000 0			Turnard		
Water by AAS-C	GF: ASTM D3559-03D, U	JS EPA 200.9	<u> </u>		5 Days	<u> </u>	_
		•					
Sample #	Location	Outlet Type	Time	Cooler Model	·	Lab ID	Results
114.6-37	134	В	12:30	0			
114.6-38 114.6-39	134	S	12:31	0			
114.6-40	131	S	12:32	0			
114.6-41	131	B S	12:33 12:33	0			
114.6-42	135	S	12:35	0			
114.6-43	135		12:35	0			
114.6-44	135	S	12:35	0	— I —		
114.6-45	130	S	9:07	0		· · · · · · · · · · · · · · · · · · ·	
114.6-46	130	В	9:07	0			-
114.6-47	130	S	9:07	0		······································	- -
114.6-48	136	S	12:41	0	\neg \vdash		
114.6-49	136	В	12:41	0			
114.6-50	136	S	12:41	0		····	
114.6-51	129	S	12:44	0			
114.6-52	129	В	12:45	0			
114.6-53	129	S	12:46	0		1.	
114.6-54	129	S	12:47	0			
Notes: Please e-mail lat	o results to labs@stohler	nv.com					
	Mike Irwin		Stohl Env:	Mike Irwin	Date: 9/2	6/2016	•
Relinquished By:	_E. + Felg	2_ Print Name	Stohl Env:	Eric Henderson Jr.	Date: <u>9/2</u>	7/2016	
Received (Name	e / Lab):		Date:		Time:		
Sample Login (N	lame / Lab):		Date:		Time:		
Analysis (Name	/ Lab):		Date:		Time:		
QA/QC Review (Name / Lab):		Date:		Time:		
Archived / Releas	sed:QA/QC In	nterLAB Use:	Date:		Time:		
		Page	3_ of <u>7_</u>				



Submitted to: (Lab Name)

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES.
4169 ÁLLENDÁLE PKWY, BUFFALO, NEW YORK 14219
4716 A 312-0670 B 2716 A 317-8087

STOHL Job# 2016L-114.6

. 3	www.stoblenvironmental.com	92				
Client: Frontier C	SD		Contact:	Bob Markel		
Building: Pinehurst	Elem.		Location:	3050 Fairway Ct., Lake	eview NY	
<u>LEAD</u> Water by AAS-GF: A	STM D3559-03D, US	S EPA 200.9	X		Turnaround 5 Days	
Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
114.6-55	137	В	12:48	0	Labib	Results
114.6-56	137	S	12:49	0	÷	_
114.6-57	128	s	12:50	0		
114.6-58	128	В	12:50	0		
114.6-59	128	S	12:50	0		
114.6-60	127	S	12:50	0		-
114.6-61	: 127	В	12:50	0		
114.6-62	127	S	12:50	0		
114.6-63	138BR	S	12:50	. 0		
114.6-64	140Jan	S .	12:50	0		
114.6-65	140BR	S	12:59	0		
114.6-66	139A	S	1:01	0		
114.6-67	141BR	S	1:05	0		
114.6-68	141	S	1:06	0		
114.6-69	141BR	S	1:07	0		
114.6-70	143	S	1:09	0		
114.6-71	143	S	1:10	0		
114.6-72	143	S	1:10	0		
Notes: Please e-mail lab res	sults to labs@stohlen	v.com				
Sampled By: M	ike Irwin	Print Name	Stohl Env:	Mike Irwin E	Date: 9/26/2016	
Relinquished By:	ike Irwin	Print Name	Stohl Env: E	ric Henderson Jr. [Date: <u>9/27/2016</u>	
Received (Name / La	ab):		Date:		ime:	
Sample Login (Name	e / Lab):		Date:	ТТ	ime:	* * *
Analysis (Name / Lat	o):		Date:	Т	ime:	
QA/QC Review (Nam	ne / Lab):		Date:	T	ïme:	18 11 1
Archived / Released:	QA/QC Inf	terLAB Use:	Date:	Т	ime:	

Page

4 of <u>7</u>



Submitted to: (Lab Name)

Schneider

ENVIRONMENTAL COI	NSULTANTS - A MEMBER OF THE STOM 69 ALLENDALE PKWY, BUENALO, NEW YORK I 27(16) 312-0070 2 (716) 312-8092 www.stollenvironmental.com	GROUP OF COMPANIES 4217		STOHL J	lob #	2016L-11	4.6
Client: Fronti	er CSD		Contact: E	Bob Markel			
Building: Pineh	urst Elem.		Location: 6	050 Fairway Ct., L	akeview NY	,	
LEAD Water by AAS-G	F: ASTM D3559-03D, US E	PA 200 0	х		Turnard		
	· · · · · · · · · · · · · · · · · · ·	_			5 Days		_
Sample #	Location	Outlet Type	Time	Cooler Model		Lab ID	Results
114.6-73	143A	S	1:20	0		<u> </u>	IXESUITS
114.6-74	143A	S	1:20	0			
114.6-75	143A	S	1:21	0	— I —		
114.6-76	143A	Ś	1:21	0			
114.6-77	144	S	1:23	0			
114.6-78	145Jan	S	1:24	0			
114.6-79	146	S	1:25	0			
114.6-80	148	S	1:26	0	—— I —		1
114.6-81	149	S	1:27	0			-
114.6-82	CO 149	DF	1:28	0			
114.6-83	150	S	1:29	0			
114.6-84	151	S	1:31	0			
114.6-85	152	S	1:32	0			
114.6-86	CO 154	DF	1:33.	0		<u> </u>	
114.6-87	154	S	1:35	0			
114.6-88	CO 126	DF	1:42	0			
114.6-89	125	DF	1:48	0			
114.6-90	125	S	1:49	0			
Notes: Please e-mail lab	o results to labs@stohlenv.co	m					
Sampled By:	Mike Irwin	Print Name	Stohl Env:	Mike Irwin	Date: 9/2	6/2016	
Relinquished By:	_E. Helg.	_ Print Name	Stohl Env. Er	ic Henderson Jr.	Date: <u>9/2</u>	7/2016	
Received (Name	/ Lab):		Date:		Time:		
Sample Login (N	ame / Lab):	· · · · · · · · · · · · · · · · · · ·	Date:		Time:		
Analysis (Name /	Lab):		Date:	· .	Time:		· · · · · · · · · · · · · · · · · · ·
QA/QC Review (Name):		Date:		Time:		
Archived / Releas	sed:QA/QC InterL	AB Use:	Date:		Time:		
		Page	5 of 7				



			Submitted to: (Lab Nar		Name) Schneider		
4169 AL	TANTS - A MEMBER OF THE ST LENGALE PXWY, BUFFALO, NEW YO	#K 14219		STOHL.	Job#	2016L-1	14.6
** (716)312-0020 ** (716)312-0092 ***********************************				: -			
Client: Frontier C	SD		Contac	t: Bob Markel			
Building: Pinehurst	Elem.		Location	n: <u>6050 Fairway Ct., I</u>	_akeview N`	Y	
LEAD					Turnar	ound	
	ASTM D3559-03D, US	EPA 200.9	X		5 Days		
Sample #	Location	Outlet Type	Time	Cooler Mode		Lab ID	Results
114.6-91	125	S	1:49	0		20015	Results
114.6-92	125	S	1:50	0	 }-		
114.6-93	125	S	1:50	0			
114.6-94	157BR	S	1:56	. 0			
114.6-95	157BR	S	1:56	0			
114.6-96	157Jan	S	1:57	. 0			
114.6-97	123Jan	S	2:02	. 0			
114.6-98	123BR	S	2:03	. 0			
114.6-99	123BR	S	2:03	0			
114.6-100	158	S	2:05	. 0			1.0
114.6-101	158	S	2:06	0			
114.6-102	160BR	S	2:08	0			
114.6-103	163	S	2:25	0	_		
114.6-104 114.6-105	163	S	2:26	0			
114.6-106	163	S	2:27	0			
114.6-107	163 163	S	2:28	0	<u> </u>		
114.6-108	163	S S	2:29	0	II-		
114.0-100	103	5	2:30	0			
Notes:				•			
Please e-mail lab res	sults to labs@stohlenv	com					
Sampled By: M	like Irwin	Print Name	Stohl Env:	Mike Irwin	Date: 9/2	06/2016	
	4	- Trink Name	Otom Env.	WIIKE II WIII	Date. 9/2	.0/2010	
Relinquished By:	i thou	Print Name	Stohl Env:	Eric Henderson Jr.	Date: <u>9/2</u>	7/2016	
Received (Name / La	ab):		Date:	· · · · · · · · · · · · · · · · · · ·	Time:		
Sample Login (Name	e / Lab):		Date:		Time:		
Analysis (Name / Lab	o):		Date:		Time:		
QA/QC Review (Nam	ne / Lab):		Date:		Time:		-
Archived / Released:	QA/QC Inte	erLAB Use:	Date:		Time:		

6 of <u>7</u>



Submitted to: (Lab Name)

Schneider

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STORL GROUP OF COMPANIES 4169 ALIENDALE PRWY, BUPRALO, NEW YORK (4219 (716) 312-0970 (716) 312-8092 www.storionienvironmental.com					STOHL	Job #	2016L-1	14.6	
Client:	lient: Frontier CSD				Contact: Bob Markel				
Building:	ng: Pinehurst Elem.				Location: 6050 Fairway Ct., Lakeview NY				
LEAD			······································			Tui	rnaround	· · · · · · · · · · · · · · · · · · ·	
Water by AAS-GF: ASTM D3559-03D, US EPA 200.9				х	5 Days				
Samp	ele# Loc	ation	Outlet Type	Time	Cooler Mode		Lab ID	Results	
114.6-		163	Cook vessel	2:31	0				
114.6		163	S	2:32	0				
114.6-		163	S	2:33	0				
114.6-		163	S	2:34	. 0				
114.6-		163	HB	2:35	0				
114.6-		166	S	2:37	0				
114.6-		55BR	S	2:38	0				
114.6- 114.6-		167	S	2:39	0				
114.6-		165 165	WMF	2:42	0		·		
114.6-		ide 154	WMTC HB	2:46 3:09	0		***	<u> </u>	
114.6-		ide 104	HB	3:26	0				
111.0	120 Odio	ide 104		3.20	0				
			 		0				
			-		0				
					0				
					0			- 	
				5	0				
Notes: Please e-r	nail lab results to labs	@stohlenv.c	om						
Sampled E	By: Mike Irwin	ν	Print Name	Stohl Env:	Mike Irwin	Date:	9/26/2016		
Relinquished By: Print Name				Stohl Env: Eric Henderson Jr.		Date:	: 9/27/2016		
Received (Name / Lab):				Date:		Time:	e:		
Sample Login (Name / Lab):				Date:		Time:	ime:		
Analysis (Name / Lab):				Date:		Time:	Time:		
QA/QC Review (Name / Lab):				Date:		Time:			
Archived / Released:QA/QC InterLAB Use:				Date:		Time:			

Page

<u>7</u> of <u>7</u>