

1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples at or Below the NYS Action level of 15 ppb	Number of Samples Above the NYS Action Level of 15 ppb	Number of Samples Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
Big Tree Elementary	2/21/2020	101	99	2	N/A	N/A
Blasdell Elementary	2/21/2020	115	96	19	N/A	N/A

** Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples at or Below the NYS Action level of 15 ppb	Number of Samples Above the NYS Action Level of 15 ppb	Number of Samples Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
Cloverbank Elementary	2/21/2020	114	98	16	N/A	N/A

** Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples at or Below the NYS Action level of 15 ppb	Number of Samples Above the NYS Action Level of 15 ppb	Number of Samples Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
Frontier Middle School	2/21/2020	143	123	20	N/A	N/A

** Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples at or Below the NYS Action level of 15 ppb	Number of Samples Above the NYS Action Level of 15 ppb	Number of Samples Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
Pinehurst Elementary	2/21/2020	104	97	7	N/A	N/A

** Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples at or Below the NYS Action level of 15 ppb	Number of Samples Above the NYS Action Level of 15 ppb	Number of Samples Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
Education Center	2/26/2020	17	9	8	N/A	N/A

** Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples at or Below the NYS Action level of 15 ppb	Number of Samples Above the NYS Action Level of 15 ppb	Number of Samples Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
Frontier High School	2/26/2020	197	171	26	N/A	N/A

** Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration in excess of the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.